

River Trails Early Learning Center Remodeling

Mt Prospect, Illinois

Pre-Certified:

PHIUS + 2018

PHIUS + SOURCE ZERO

ICECF Net Zero Building Grant



Tom Boeman
boeman
design

Boeman Design LLC

2607 West Leland Avenue | Chicago, IL 60625



FGM ARCHITECTS

Project Team



Owner

FGM ARCHITECTS

Project Architect



MEP/FP Engineer



Construction Manager



Photovoltaic Design

boeman
design

Certified Passive House Consultant



PHIUS Rater/Certifier



DISTRICT 26 EARLY
LEARNING CENTER

What's Interesting about this Project

- It's a ***Retrofit***
- It's ***Net Zero***
- It's an ***Educational Building***
- Its performance will be ***Monitored*** as a condition of Grant Funding.
- ***My First CPHC*** Project.

Project Scope

- First Remodeling of 1960s Modern 27,930 SF single story masonry Elementary School.
- Building includes School Offices, Classrooms, District Offices and Multipurpose room.
- Pursuing Net Zero Building Grant through the Illinois Clean Energy Community Foundation (ICECF)
- New Exterior Envelope including Walls, Roof, Doors and Windows.
- New HVAC System.
- New Interior and Exterior lighting systems.
- New roof-mounted PV array to offset source energy.

ICECF Net Zero Building Grant



Net Zero Energy Building Program

The Foundation's **Net Zero Energy Building Program** will award grants to new construction or retrofit projects that achieve site net zero energy performance or better, over the course of a year. Buildings must, at a minimum, offset all of their energy consumption with on-site generation from renewable resources. Grants will be paid incrementally, with full payment contingent on actual building performance.

The program goal is to encourage exemplary buildings that bring together beautiful design and careful construction to maximize energy efficiency, showcase renewable energy and, by educating the public and professionals, help pave the way for a larger shift in the building sector. The Foundation aims to fund projects that demonstrate that net zero energy buildings are realistic and achievable. These flagship projects will add to the knowledge base on net zero building design and operation.



Grant requires dramatic reductions in energy consumption *prior* to offsetting with renewables. Reductions substantiated by: PHIUS + 2018 or Petal (Energy) Living Building Certification

Grant requires all Renewable Energy to be generated on site.

Grant requires Monitoring of energy use and renewable production for 12 consecutive months to verify modeling

ICECF expects an EUI in the “high teens” to “low twenties”

PHIUS+ Certification & ICECF Grant Process

Design

Construction

Post Construction



PHIUS Requirements

Pre - Certification

Final - Certification



Energy Model and Documentation



On-Site QA/QC Testing/Inspection



ICECF Requirements

Pre Proposal

Full Proposal

Monitoring

12 Consecutive Months Monitoring

First Grant Payout (30%)

Second Grant Payout (30%)

Final Grant Payout (40%)

PHIUS + Criteria Calculator: Inputs

PHIUS+ 2018 Final Calculator v2

PHIUS+ 2018 Space Conditioning Criteria Calculator v2

METHOD: CALCULATOR ▾
UNITS: IMPERIAL (IP) ▾

STATE / PROVINCE: ILLINOIS ▾
CITY: CHICAGO OHARE INTL AP ▾

Envelope Area (ft²) / iCFA (ft²) **2.58** or enter here:
iCFA (ft²) / person **527** or enter here:

*Calculator method is used for official certification targets.

Space Conditioning Criteria

Annual Heating Demand	8.3	kBTU/ft ² yr
Annual Cooling Demand	7.8	kBTU/ft ² yr
Peak Heating Load	6.3	BTU/ft ² hr
Peak Cooling Load	4.0	BTU/ft ² hr

Typed entry will override sliding scale.

The results of the CALCULATOR method take precedence over the ESTIMATOR method.

Update

Reset

Inputs

Local Climate Data Chicago Illinois

- Envelope to floor area: **2.58**
- iCFA **27,930 Sf**
- Max Occupancy **297**
(used for peak load)
- Average Occupancy **53**
(used for annual demand)

PHIUS + Criteria Calculator: Targets

PHIUS+ 2018 Final Calculator v2

PHIUS+ 2018 Space Conditioning Criteria Calculator v2

METHOD: CALCULATOR ▾
UNITS: IMPERIAL (IP) ▾

STATE / PROVINCE: ILLINOIS ▾
CITY: CHICAGO OHARE INTL AP ▾

Envelope Area (ft²) / iCFA (ft²) **2.58** or enter here:

iCFA (ft²) / person **527** or enter here:

*Calculator method is used for official certification targets.

Space Conditioning Criteria		
Annual Heating Demand	8.3	kBTU/ft ² yr
Annual Cooling Demand	7.8	kBTU/ft ² yr
Peak Heating Load	6.3	BTU/ft ² hr
Peak Cooling Load	4.0	BTU/ft ² hr

Typed entry will override sliding scale.
The results of the CALCULATOR method take precedence over the ESTIMATOR method.

Targets:

Project Specific Targets for:

- Annual Heating Demand: **8.3 kBTU/ft²yr**
- Annual Cooling Demand: **7.8 kBTU/ft²yr**
- Peak Heating Load: **6.3 BTU/ft²hr**
- Peak Cooling Load: **4.0 BTU/ft²hr**

Universal Targets for:

- Source Energy: **34.8 kBTU/ ft² yr** (110 kWh/ m² yr)
- Air Tightness: q₅₀ ≤ **0.060 CFM₅₀/ft²** (Envelope)

Existing Building



Existing Building



Existing Building




Existing Building



Existing Building

(9) WEST CLASSROOMS



Physical Opportunities

- All new exterior envelope including wall finishes, glazing system and roofing.
- All new mechanical systems.
- All new Lighting Systems
- No Historic features or finishes were being preserved.

Physical Challenges

- “Pancake” building with relatively high surface area to iCFA. Less than optimal form.
- No opportunities to adjust window orientation or massing.
- Existing un-insulated slab on grade.

New to Phius + Certification Guide V.3.

1.5.6 Retrofit Projects

The criteria for retrofit projects are the same as for new construction, except that a case-by-case energy allowance may be made for a foundation perimeter thermal bridge or other such hard-to-fix structural thermal bridges - provided that the design is also “damage-free,” that is, low risk from a moisture point of view.

The allowance noted above may also apply to uninsulated slab-on-grade conditions. To determine the allowance in WUFI Passive, the prescriptive path R-value under the slab should be modeled. The difference in modeled performance results is equivalent to the allowance that may be applied.

Process Opportunities

- The Owner had a strong commitment to achieving Net Zero
- The Architect, FGM, had a strong technical grasp of the issues. Adopted a straightforward “Textbook” approach
- The MEP Engineer, IMEG, had Net Zero building Experience
- The Builder Nicolas and Associates had 2 team members take the PHIUS Builder training in preparation for the project.


Process Challenges

- The CPHC was brought in at 100% Design Development
- The building was already designed as “Net Zero”

..... But with IECC levels of insulation



Thermal Envelope - Wall Section: 100% DD



R-30 Roof

Tapered Polyisocyanurate

R-15 Walls (Total R-18)

2 1/2" Polyisocyanurate


R-15 Slab Edge

2 1/2" Polyisocyanurate

2'-0" Deep



Thermal Envelope - Wall Section: Final CDs



R-80 Roof (Effective)

Tapered Polyisocyanurate (10" Min – 20" Max)

R-24 Walls (Total R-27)

4" Polyisocyanurate
(Maximum accepted by Cladding Manufacturer)


R-30 Slab Edge/Foundation Wall

6" Polyisocyanurate
2'-0" deep




Thermal Envelope – Wall Detail

INTERIOR




EXTERIOR




KNIGHT CI RAIN SCREEN SYSTEM



Thermal Envelope - Windows: 100% DD



Typical Classroom Glazing



Glass:

U_{cog} **0.20**
Double Glazed

Frame:


U_{frame} **~0.88**

Spandrel Glass Above Ceiling


Two Operable Windows



Thermal Envelope - Windows: Final CDs



Typical Classroom Glazing



Glass:

U_{cog} **0.111**

Triple Glazed Double Coated

Frame:


U_{frame} **~0.88**

**Eliminate Spandrel Glass
above Ceiling**

**Reduce to One Operable
Window**



Thermal Envelope - Windows



Kawneer 1600UT
Triple glazed and Fiberglass
Pressure Plates

Calculation based on ISO 15099

Product name: 1600UT System™ Curtain Wall- Fiberglass PP		Center-of-glass properties				
ASHRAE/IECC/ DOE North American Climate Zone	South-facing North, East, West -facing	 Passive House Institute US		Vitro SB60 / Argon / Clear / Argon / SB60 (6mm/6mm/6mm) 45mm IG No Grids		
Climate specific recommendations:		Whole-window installed U-value		Ucog-Value		
		W/m2K	BTU/hr.ft2.F	SHGC	W/m2K	BTU/hr.ft2.F
8		1.10	0.19	0.329	0.684	0.121
7		1.07	0.19	0.329	0.656	0.116
6		1.05	0.18	0.329	0.635	0.112
5		1.05	0.18	0.329	0.632	0.111
4		1.04	0.18	0.329	0.628	0.111
Marine North		1.04	0.18	0.329	0.627	0.110
Marine South	✓	1.04	0.18	0.329	0.627	0.111
3	✓	1.04	0.18	0.329	0.627	0.110
2 West		1.05	0.18	0.329	0.632	0.111
2 East		1.05	0.18	0.329	0.632	0.111

1600UT System™ Curtain Wall- Kommerling TPS Spacer Horizontal two lite left	FRAME				Psi-spacer	
	Frame height		U-frame		Ψ	
	mm	in	W/m2K	BTU/hr.ft2.F	W/mK	BTU/hr.ft.F
left head	35	1.38	4.81	0.85	-0.001	-0.001
left sill	35	1.38	4.82	0.85	-0.001	-0.001
left jamb	35	1.38	5.17	0.91	-0.001	-0.001
right MR	35	1.38	5.17	0.91	-0.001	-0.001

1600UT System™ Curtain Wall- Fi Kommerling TPS Spacer Horizontal two lite right	FRAME				Psi-spacer		Psi-opaque
	Frame height		U-frame		Ψ		
	mm	in	W/m2K	BTU/hr.ft2.F	W/mK	BTU/hr.ft.F	W/mK
right head	35	1.38	4.81	0.85	-0.001	-0.001	0.180
right sill	35	1.38	4.82	0.85	-0.001	-0.001	BTU/hr.ft.F
right jamb	35	1.38	5.17	0.91	-0.001	-0.001	0.104
left MR	35	1.38	5.17	0.91	-0.001	-0.001	Grade C


For horizontal slider the right MR is the right jamb for the left segment and the left MR is the left jamb for the right segment

Valid through June 2021

PHIUS Verified Window Data.



Continuous Air Barrier



Air Barrier Components:

Roof Membrane

Fluid Applied Air Barrier

Wall Sheathing and Foundation Face Below.

Stainless Steel Transition Flashing.


Between Fluid Applied Air Barrier and Roof Membrane.

Silicone Window Flashing

Clamped into Glazing Channel




Continuous Air Barrier




TYPICAL PARAPET




Continuous Air Barrier



TYPICAL WINDOW JAMB



TYPICAL WINDOW SILL




Mechanical System Selection

System/Plant	EUI		Energy Cost	
	(kBtu/sqft/yr)	% Savings	(\$/yr)	% Savings
Baseline: 90.1-2013	75	-	\$ 30,128	-
Single Pipe Hybrid Geothermal	20	74%	\$ 21,854	27%
Single Pipe 100% Geothermal	20	74%	\$ 21,682	28%
VRF Hybrid Geothermal	17	78%	\$ 18,264	39%
VRF 100% Geothermal	16	78%	\$ 18,026	40%
VRF Air Cooled	23	69%	\$ 25,327	16%

Energy Source	Utility Costs	
Electric	\$0.086 per kWh	\$0.025 per kBtu
Natural Gas	\$0.386 per therm	\$0.004 per kBtu

Envelope Assumptions	
Exterior Wall:	R-18 (U-0.055)
Roof:	U-0.032
Windows:	U-0.42 and SHGC: 0.40
Window to Wall Ratio:	35%



DOAS COUPLED WITH VRF SYSTEM





DEDICATED OUTSIDE AIR SYSTEM (DOAS)

DOAS Components:

ECM Motor Fan

Electronically Commutated Motor

Energy Recovery Wheel

All building exhaust is recovered


Digital Scroll Compressors

Match Compressor output to load

Heat Pump Heating

Coefficient of Performance of 2.3

Operates in heating down to 0°F





DEDICATED OUTSIDE AIR SYSTEM (DOAS)

DOAS Operating Modes:


Economizer Mode

Manages Moisture content of air
Optimizes Dew point of outside air
for Supply air

Free Cooling Mode


Provides additional cooling through
ventilation when Outside air
conditions are cooler than inside.

Dehumidification





DEDICATED OUTSIDE AIR SYSTEM (DOAS)





Certificate of Product Ratings

AHRI Certified Reference Number : 518128 Date : 11-20-2019 Model Status : Active
 Old AHRI Reference Number :
 Brand Name : Airchange
 Product Type : Wheel
 Model Number : ERC-3014C
 Selection Software Name :
 Selection Software Version :

Rated as follows in accordance with the latest edition of ANSI/AHRI 1060 (I-P) Performance Rating of Air-to-Air Exchangers for Energy Recovery Ventilation Equipment and subject to rating accuracy by AHRI-sponsored, independent, third party testing:

Nominal Air Flow (scfm) : 1400
 Pressure Drop (at nominal airflow, in. H₂O) : 1.00

Leakage Ratings	PressureDiff	EATR(%)	OACF	PurgeAngle
Test 1 :	0	2.4	1.04	N/A
Test 2 :	0.5	0.8	1.08	2
Test 3 :	1	0.0	1.10	1

	Sensible(%)	Latent(%)	Total(%)
100% Air Flow Heating :	76	70	74
75 % Air Flow Heating :	80	75	78
100% Air Flow Cooling :	76	70	72
75% Air Flow Cooling :	80	75	77

	Net Sensible(%)	Net Latent(%)	Net Total(%)
100% Air Flow Heating :	76	70	74
75 % Air Flow Heating :	80	75	78
100% Air Flow Cooling :	74	69	72
75% Air Flow Cooling :	80	74	77



Active Model Status are those that an AHRI Certification Program Participant is currently producing AND selling or offering for sale. OR new models that are being marketed but are not yet being produced. *Production Stopped* Model Status are those that an AHRI Certification Program Participant is no longer producing BUT is still selling or offering for sale.
Ratings that are accompanied by WAS indicate an involuntary re-rate. The new published rating is shown along with the previous (i.e. WAS) rating.

DISCLAIMER
 AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS
 This certificate and its contents are proprietary products of AHRI. This certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced, copied, disseminated, entered into a computer database, or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION
 The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2019 Air-Conditioning, Heating, and Refrigeration Institute

CERTIFICATE NO.: 132187591191029440

AHRI ERV performance extrapolation - straight line method


WUFI Inputs			
Sensible Recovery Efficiency	0.81	Total Design Airflow	
		10,435	
Humidity Recovery Efficiency	0.75		

Model	Units	CFM	Net Sensible (%)		Net Latent (%)		Weighted Sensible Recovery	Weighted Humidity Recovery	Net Sensible Slope		Net Latent Slope	
			Heating	Cooling	Heating	Cooling			Heating	Cooling	Heating	Cooling
DOAS-1	100% AHRI Rated Airflow	1,400	76	74	70	69						
	75% AHRI Rated Airflow	1,050	80	80	75	74						
	Design airflow	980	80.8	81.2	76.0	75.0	0.0759	0.0714				
DOAS-2	100% AHRI Rated Airflow	1,400	76	74	70	69			0.0114	0.0171	0.0143	0.0143
	75% AHRI Rated Airflow	1,050	80	80	75	74						
	Design airflow	1,570	74.1	71.1	67.6	66.6	0.1114	0.1017				
DOAS-3	100% AHRI Rated Airflow	1,400	76	74	70	69			0.0114	0.0171	0.0143	0.0143
	75% AHRI Rated Airflow	1,050	80	80	75	74						
	Design airflow	930	81.4	82.1	76.7	75.7	0.0725	0.0684				
DOAS-4	100% AHRI Rated Airflow	1,400	76	74	70	69			0.0114	0.0171	0.0143	0.0143
	75% AHRI Rated Airflow	1,050	80	80	75	74						
	Design airflow	990	80.7	81.0	75.9	74.9	0.0765	0.0720				
DOAS-5	100% AHRI Rated Airflow	1,400	76	74	70	69			0.0114	0.0171	0.0143	0.0143
	75% AHRI Rated Airflow	1,050	80	80	75	74						
	Design airflow	910	81.6	82.4	77.0	76.0	0.0712	0.0671				
DOAS-6	100% AHRI Rated Airflow	1,400	76	74	70	69			0.0114	0.0171	0.0143	0.0143
	75% AHRI Rated Airflow	1,050	80	80	75	74						
	Design airflow	700	84.0	86.0	80.0	79.0	0.0563	0.0537				
DOAS-7	100% AHRI Rated Airflow	1,400	76	74	70	69			0.0114	0.0171	0.0143	0.0143
	75% AHRI Rated Airflow	1,050	80	80	75	74						
	Design airflow	1,565	74.1	71.2	67.6	66.6	0.1112	0.1014				
DOAS-8	100% AHRI Rated Airflow	1,400	76	74	70	69			0.0114	0.0171	0.0143	0.0143
	75% AHRI Rated Airflow	1,050	80	80	75	74						
	Design airflow	950	81.1	81.7	76.4	75.4	0.0739	0.0696				
RTU-1	100% AHRI Rated Airflow	3,200	65	64	61	60			0.0200	0.0143	0.0143	0.0143
	75% AHRI Rated Airflow	2,400	72	69	66	65						
	Design airflow	1,840	92.2	83.4	80.4	79.4	0.1626	0.1418				
	100% AHRI Rated Airflow								0.0000	0.0000	0.0000	0.0000
	75% AHRI Rated Airflow	0										
	Design airflow		0.0	0.0	0.0	0.0	0.0000	0.0000				
	100% AHRI Rated Airflow								0.0000	0.0000	0.0000	0.0000
	75% AHRI Rated Airflow	0										
	Design airflow		0.0	0.0	0.0	0.0	0.0000	0.0000				
	100% AHRI Rated Airflow								0.0000	0.0000	0.0000	0.0000
	75% AHRI Rated Airflow	0										
	Design airflow		0.0	0.0	0.0	0.0	0.0000	0.0000				
	100% AHRI Rated Airflow								0.0000	0.0000	0.0000	0.0000
	75% AHRI Rated Airflow	0										
	Design airflow		0.0	0.0	0.0	0.0	0.0000	0.0000				




DEDICATED OUTSIDE AIR SYSTEM (DOAS)

(9) ROOFTOP DOAS UNITS





DEDICATED OUTSIDE AIR SYSTEM (DOAS)



Ventilation Air Distribution:

Ducted Supply to Classrooms, Corridors and other occupied spaces.

Plenum Return from Occupied Spaces

Ducted Return from Restrooms




DEDICATED OUTSIDE AIR SYSTEM (DOAS)

*Make sure there is no direct exhaust ventilation.
Except as required for kitchens or combustion
appliances.*

*Align Ventilation Zones with Operational Zones as
much as possible*

*Use Heat pump for DOAS Ventilation air
Conditioning*



Variable Refrigerant Flow System (VRF)

VRF System Components:

Air Source Heat Pump

High Efficiency COP: 3.66

Branch Controllers


Energy Recovery allows different rooms on the same branch controller to be simultaneously heating and cooling.

Terminal Units

Located in each conditioned space.




Air Source
Condensing Unit




Branch Controller




Terminal Unit - Cassette






Variable Refrigerant Flow System (VRF)


(3) AIR SOURCE HEATPUMPS






Variable Refrigerant Flow System (VRF)

TERMINAL UNITS AIR SOURCED HEAT PUMP (ON ROOF)




BRANCH CONTROLLER


REFRIGERANT LINES



Variable Refrigerant Flow System (VRF)

Typical Classroom






Variable Refrigerant Flow System (VRF)

Make sure you know what things look like. Team was surprised by the shrouds over the VRF Units.






Variable Refrigerant Flow System (VRF)


Zone VRF Branch controllers to take advantage of simultaneous heating and cooling efficiencies. Consider what scenarios might require simultaneous heating and cooling and Zone Accordingly.

Consider implications of running refrigerant lines throughout the interior space.






Energy Efficient Lighting and DHW Systems

- All LED Lighting
- All lighting on “Vacancy” Sensors or “Occupancy” Sensor where possible.
- DHW loop on thermostat controlled “On Demand” System.
- Measurement and Verification Electrical Panels for energy monitoring



Energy Monitoring



Energy Monitoring

*For a Monitored Project to be successful. Not only does the modeling and execution have to be done right... The **Occupants have to behave** as expected.*

Outreach and Education are Critical

Operational Considerations - Scheduling


Operating schedule impacts occupant Load, lighting load, and ventilation rates

Park View School
River Trails School District 26

Occupancy Summary for WUFI	Occupant Type	Occupancy	Start Time	End Time	Hours	Days/Year	Include in Max (only concurrent uses)	Max	Occupant Hours per Year	Average Occupancy (= Occupant Hours per yr / 8760 hrs per yr)
School Year (Heating Season)										
Educational										
Classrooms	Children (age 0-10)	250	8:30 AM	3:00 PM	6.50	185	y	250	300625	34.32
Classrooms	Adult Standing or Light Work	25	7:00 AM	5:00 PM	10.00	185	y	25	46250	5.28
School Offices	Adult Standing or Light Work	10	7:00 AM	5:00 PM	10.00	210	y	10	21000	2.40
District Offices	Adult Standing or Light Work	12	6:00 AM	6:00 PM	12.00	260	y	12	37440	4.27
Extracurricular School Use										
Multipurpose Room	Children (age 0-10)	160	6:00 PM	10:00 PM	4.00	5		0	3200	0.37
Multipurpose During School Day (For Ventilation) daytime occupancy is from students and teachers accounted for in Classroom Count)		0	8:30 AM	5:00 PM	8.00	185		0	0	0.00
Public Use										
Multipurpose (Adult) - AM Child Care	Adult Standing or Light Work	3	6:00 AM	8:30 AM	2.00	185		0	1110	0.13
Multipurpose (Adult) - PM Child Care	Adult Standing or Light Work	3	3:00 PM	6:30 PM	3.50	185		0	1943	0.22
Multipurpose (Children) - AM Child Care	Children (age 0-10)	15	6:00 AM	8:30 AM	2.50	185		0	6938	0.79
Multipurpose (Children) - PM Child Care	Children (age 0-10)	15	3:00 PM	6:30 PM	3.00	185		0	8325	0.95
Classroom (Public Use)	Adults	20	7:00 PM	9:00 PM	2.00	87		0	3480	0.40
Summer (Cooling Season)										
Educational										
Classrooms Pre K Summer	Children (age 0-10)	50	8:00 AM	12:00 PM	4.00	58		0	11600	1.32
Public										
Multipurpose (Children) - Camp	Children (age 0-10)	25	8:00 AM	4:00 PM	8.00	58		0	11600	1.32
Multipurpose (Adult) - Camp	Adult Standing or Light Work	2	8:00 AM	4:00 PM	8.00	58		0	928	0.11
Multipurpose (Children) - PM	Children (age 0-10)	30	7:00 PM	9:00 PM	2.00	24		0	1440	0.16
Multipurpose (Adult) - PM	Adult Standing or Light Work	2	7:00 PM	9:00 PM	2.00	24		0	96	0.01
Classrooms - Camp	Children (age 0-10)	15	8:00 AM	4:00 PM	8.00	58		0	6960	0.79
Classrooms - Camp	Adult Standing or Light Work	1	8:00 AM	4:00 PM	8.00	58		0	464	0.05
		638						297	463398.00	53
								WUFI Peak Occupancy	WUFI Demand Occupancy	


Operational Considerations - Scheduling

Tighten the Schedule and Make sure the owner and operating engineer are on board with the ventilation strategy.



Offset Site Energy with Renewables.

- ICECF Grant required all Renewable production to be “On Site”
- 166.4 KW Roof top Photovoltaic Array.




Model Results

PASSIVEHOUSE REQUIREMENTS

Certificate criteria: **PHIUS+ 2018**

Heating demand

specific: **7.97** kBtu/ft²yr
 target: **8.3** kBtu/ft²yr
 total: **222,607.52** kBtu/yr




Cooling demand

sensible: **0.38** kBtu/ft²yr
 latent: **1.16** kBtu/ft²yr
 specific: **1.54** kBtu/ft²yr
 target: **5.3** kBtu/ft²yr
 total: **43,126.85** kBtu/yr




Heating load

specific: **5.99** Btu/hr ft²
 target: **6.3** Btu/hr ft²
 total: **167,268.2** Btu/hr




Cooling load

specific: **2.31** Btu/hr ft²
 target: **3.9** Btu/hr ft²
 total: **64,465.63** Btu/hr




Source energy

total: **545,688.86** kWh/yr
 specific: **66.66** kBtu/ft²yr
 target: **34.8** kBtu/ft²yr
 total: **1,861,783.88** kBtu/yr
 specific: **66.66** kBtu/ft²yr




Site energy

total: **664,922.81** kBtu/yr
 specific: **23.81** kBtu/ft²yr
 total: **194,888.88** kWh/yr
 specific: **6.98** kWh/ft²



Air tightness

ACH50: **0.92** 1/hr
 CFM50 per envelope area: **0.06** cfm/ft²
 target: **0.92** 1/hr
 target CFM50: **0.06** cfm/ft²



WUFI® Passive V.3.2.0.1 | 16176 - Park View School Renovation - Tom Boeman | 0. Energy Model | 16176 Park View School Renovation - Energy Model Submission 3_PRE-CERT.mwp

File Input Options Database Help

Scope: **Passive house verification** | English | Outer dimensions | PHIUS+ 2018 | Assign data | Project/Cases/Case 1: PHIUS+ 2018 - Uninsulated slab / Localization/Climate: User defined

Project: Case 1: PHIUS+ 2018 - Uninsulated slab

Localization/Climate: User defined

Setting	Jan.	Feb.	March	April	May	June	July	Aug.	Sept.	Oct.	Nov.	Dec.	Heating W. 1	Heating W. 2	Cooling W. 1	Cooling W. 2
Ambient [°F]	23.72	27.5	38.84	50	59.54	69.98	75.38	71.24	64.58	51.8	40.46	25.34	7.52	21.2	80.78	
Dew point	15.08	17.24	29.3	39.2	44.96	55.4	65.66	61.88	55.22	41	32.72	18.32				
Sky*	-16.24	-5.26	7.88	17.78	29.3	37.58	51.98	47.84	38.12	21.38	14.36	-11.38				
Ground*																

Solar radiation [Btu/hr ft²]

North	East	South	West	Global
8.2419E+10	1.4361E+12	1.2045E+12	6.7961E+10	1.9706E+11
6.5589E+6	3.3907E+6	9.7394E+11	1.41194E+11	2.82128E+11
17.4342E+21	8.7262E+20	8.8963E+10	1.0686E+40	2.58740E+75
3.21382E+24	0.9115E+21	1.5848E+35	8.2081E+53	2.9292E+64
3.0748E+31	3.8263E+33	3.6627E+26	2.4725E+27	5.7862E+28
3.1382E+32	9.6724E+26	2.8956E+20	2.0364E+23	7.7487E+43
1.1728E+14	5.81E+17	7.51E+20	6.04E+27	2.61E+27
5.7862E+28	5.29E+24	4.08E+10	0.19E+14	2.64E+05
9.8209E+19	8.5389E+13	6.3093E+42	7.9477E+11	1.17E+21
3.2967E+41	2.09157E+93	5.89E+16	5.912E+49	7.6613E+90
2.7895E+16	8.001E+14	2.64E+27	5.7885E+20	2.8789E+95

* Optional input, Sky/Ground: if not defined, temperatures will be estimated

Data state/results | Show warnings | Calculate WUFI shading

Heating demand: **7.97** kBtu/ft²yr

Cooling demand: **1.54** kBtu/ft²yr



Heating load: **5.99** Btu/hr ft²

Cooling load: **2.31** Btu/hr ft²

Source energy: **0** kBtu/ft²yr

Site energy: **-2.01** kBtu/ft²yr


Model Results



Field Verification



Field Verification



Purple color in ducts indicates they are connected to the outside even though intake and exhaust are taped off.

Field Verification


Loose joint between
DOAS main enclosure
and ERV module



Field Verification

DOAS Units include a large volume of air outside the building envelope. And they can leak. Provide Dampers on the interior duct connections to the units.

Field Verification




Areas of bright orange in this image indicate potential imperfections in the air seal between the wall and roof overhang.



See accompanying IR image of the same location. We recommend double-checking the integrity of the air seal between the entire wall / roof intersection at the roof overhangs on the north and south ends of the building.

Field Verification



The bright orange line running down the side of the window could be a thermal bridge and not an air leak. But we'd recommend double checking that all of the window flashing is air tight one last time before concealing it with insulation and siding.

See comment on IR image. Flashing appears to be well installed.

Field Verification

PV Framing going in



The Final Product



The Final Product



The Final Product



The Final Product



The Final Product





DISTRICT 26 EARLY
LEARNING CENTER

THANK YOU!