



phi.us

PRO FORUM



Good Morning!

Who Are We - Who Are You?

We are part of this amazing, vibrant, Phius community that is constantly evolving, challenging status quo, dogma and each other. We have created an information exchange network really comes to life at events like the Pro Forum where we can share knowledge and experience. That is what we're here to do today.



Florian Antretter
Co-Founder and Managing Director
C3rotolutions GmbH



Daniel Perez
Senior Project Director
Thornton Tomasetti



Evan Parkinson
CPHC
Utile



Galen Staengl
CEO
Staengl Engineering



Chris Thompson
Director of Preconstruction
Delphi Construction



James Ortega
Certification Program Director
Phius



Britt Clark
Project Manager
Sustainable Comfort, Inc



Isaac Elencave
Policy Specialist
Phius



Alan Gibson
Owner
GO Logic LLC



Carmel Pratt
Vice President, New Construction
Bright Power



Chris Straile
Senior Verifier
Sustainable Comfort, Inc.



Lisa White
Co-Executive Director
Phius



Prudence Ferreira
VP Sustainability + Resilience: Passive
Building Lead
Thornton Tomasetti



Ilka Cassidy
Principal / Co-Founder
Holzraum System



Graham Wright
Chief Building Scientist
Phius



Al Mitchell
Building Scientist & Certification Manager
Phius



Paul Ormond
Efficiency Engineer
MA Department of Energy Resources
(DOER)



Michael Browne
HERS Rater
Advanced Building Analysis, LLC



Zoe Rader
Building Certification Associate
Phius



Scott Haskell
Sr. Superintendent
Delphi Construction




Sharon Libby Eyerly
Quality Director
Walsh Construction Co.



Alex Giblin
Team Lead
Go Logic



Chelsey Effinger
Designer, CPHC
GO Logic



Greg Downing
Sustainability Manager
Bald Hill Builders



Chris Benedict
Owner
Chris Benedict R.A.



James Petersen
Principal
Petersen Engineering, Inc.



Joseph Lstiburek
Founding Principal
Building Science Corporation



Julie Klump
Vice President, Design and Building
Performance
POAH



Katrin Klingenberg
Co-Executive Director
Phius



Kimberly Llewellyn
Emerging Markets Sr. Product Manager
Mitsubishi Electric



Mike Steffen
Preconstruction Services
Walsh Construction Co.



Timothy McDonald
Principal
Union Flats Architecture




Keith Simon
Vice President of Design Phase Services
Salas O'Brien



Maciej Konieczny
Director of Building Technologies
New Ecology, Inc.



Kara Haggerty Wilson
RA, CPHD, NCARB
Union Flats Architecture



Steve Hessler
Principal | Designer
Holzraum System llc



Matthias Pazold
Co-Founder and Developer
C3rotolutions GmbH



Michelle Apigian
Managing Principal
ICON Architecture



John Loercher
Building Certification Associate
Phius



Haley Kalvin-Gold
Building Certification Manager
Phius



Michelle Tinner
Director of High Performance Design
Sustainable Comfort, Inc.



Daniel Clark
Building Enclosure Consultant
Thornton Tomasetti



Jeannette Penniman
Architect
Union Flats Architecture



Jeremy Dagold
Field Manager Building Performance
Consulting
CLEAResult



Jon Erickson
Senior Project Manager
CLEAResult



Cory Heaslip
VP of Project Development
Delphi Construction



Josh Edmonds
Builder
Simple Integrity



Luke McKneally
Architect, Sr. Energy Engineer
ICF

Why Are You Here?

Design	Modeling	Fundamentals
Ventilation	DHW	Heating/Cooling
Specific Project Questions	Multifamily	Climate Based Questions

Why Now?



Incentives for Phius Projects in Massachusetts

Phius projects qualify for a wide range of incentives offered by utility providers, local municipalities and the federal government. Below is a brief rundown of some of these incentives. For more information on available incentives and their requirements, visit www.phius.org.

Most Phius Projects are Eligible for:

- Mass Save New Construction Incentive
- Mass Save Training Incentive
- Low Income Housing Tax Credit Incentive
- Stretch Code
- Opt-in Net Zero Code
- Inflation Reduction Act
 - 45L for buildings 3 stories or less
 - 179d for buildings 4 stories or more
 - Clean energy Credit
 - High Efficiency Electric home Rebate Program

Passive House Incentive Structure for Multifamily Buildings (5 units or more)

Incentive Timing	Activity	Incentive Amount	Max. Incentive
Pre-Construction	Feasibility Study	Up to 100% of Feasibility Study Cost	\$5,000
Pre-Construction	Energy Modeling	Up to 75% of Energy Modeling Costs	\$500/unit, max of \$20,000
Pre-Construction	Pre-Certification	\$500/unit	N/A
Post-Construction	Certification	\$2,500/unit	N/A
Post-Construction	Net Performance Bonus	\$0.75/kwh OR \$7.50/therm	N/A

High-Efficiency Electric Home Rebate Program

Measure	Rebate
Heat Pump Water Heater	\$1,750
Heat Pump	\$8,000
Electric Stove, Cook-top, Range, Oven	\$840
Electric Wiring	\$2,500
Electric Heat Pump Clothes Dryer	\$840
Electric Load Service Upgrade	\$4,000
Insulation, Air Sealing and Ventilation	\$1,600

ENERGY STAR Programs | Through December 32, 2032

New Construction Program and Manufactured New Homes Program		
ENERGY STAR	\$2,500	
DOE Zero Energy Ready Home	\$5,000	
Multifamily New Construction	Projects Not Using Prevailing Wage	Projects Using Prevailing Wage
ENERGY STAR	\$500/unit	\$2,500/unit
DOE Zero Energy Ready Home	\$1,000/unit	\$5,000/unit

SPC 227P, Proposed Standard authorized January 16, 2019. Revised TPS approved June 22, 2021

Passive Building Design Standard

PURPOSE: This standard provides requirements for the design of buildings that have exceptionally low energy usage and that are durable, resilient, comfortable, and healthy.

SCOPE:

2.1 This standard is applicable to all new and existing buildings intended for human occupancy.

2.2 This standard provides requirements for the design, construction and plans for operation of the:

1. building envelope,
2. heating and cooling equipment and systems,
3. ventilation systems,
4. service hot water systems,
5. interior and exterior lighting systems, and
6. plug and appliance loads.

2.3 This standard does not provide requirements for the use of buildings.


2.4 This standard does not apply to process related systems or equipment.

2.5 This standard shall not be used to circumvent any safety, health, or environmental requirements.



Shaping Tomorrow's Built Environment Today

Massachusetts Building Energy Code Adoption by Municipality



Agenda

Morning


- Introduction to Team and Attendees
- Phius Project Stats
- Building Systems – Basic Concepts / Fundamentals
- Multi-family Design
- Q & A Throughout

Afternoon

- Commercial Design- Office
- Design Exercise- School, Multifamily
- Wrap-up

Phius Certification Stats| Exponential Growth Continues


Cumulative Phius Phigures (Final Certified)




Graph Credit for Phius Stat Slides
Haley Kalvin-Gold
Phius, Building Certification Manager

Phius Certification Stats| Multifamily Accounts for Majority

Phius Final Certified Projects: 2011-Present




Phius Final Certified Projects & Total iCFA: 2020-Present




Phius Certification Stats| Northeast Accounts for Vast Majority of Projects


Phius Projects & iCFA by Region



Phius Current Active Project Stats | Predominantly MF New Construction



Phius Loads & System Fundamentals



General: Energy Flows

HVAC Basics

- Sensible, Latent
- Ventilation Loads
- Phius Load Differences
- HVAC Load Inputs


DHW Basics

- Efficient Layouts
- Recirc Loops
- DHW Loads

Energy Always Flows from Higher to Lower Concentrations



Radiative Heat Transfer



Skin to Glass 40°F ΔT

$$Q = \sigma * F * (T_1^4 - T_2^4)$$

$$Q = 165 \text{ W/m}^2 \text{ or } 15 \text{ W/ft}^2$$

$$Q = 52 \text{ Btu/h/ft}^2$$

Wall R10 @40°F ΔT

$$Q = 10 \text{ Btu/h/ft}^2$$

Lighting Load 90.1-2022


$$\text{Office} = 1.00 \text{ W/ft}^2$$

Take-away:

The comparative impact on a net basis may not show up even in models that account for radiative heat transfer. However, the localized impact on comfort can be very significant.



Cooling Loads Often Dominant



Take-away:

Even in cold climates, cooling loads are usually dominant. While sensible loads can be significantly reduced, latent loads cannot. This means humidity loads and system latent control capabilities must be evaluated. This especially holds true for high occupancy density spaces.

Water is Neither Created Nor Destroyed Spontaneously



Attendees

Why are latent loads a bigger challenge in PH buildings?

1	2	3




Why are latent loads a bigger challenge in PH buildings?

1	2	3
Ventilation Loads	Lower Sensible Loads	Equipment Latent Capacity



Partial Loads are Frequent

Partial Load Conditions Hrs/Yr (50-80 & >65gr/lb)



Partial Load Conditions

Occur in Spring, Fall and mild Summer days/evenings.


Temperatures are warm but not hot and humidity is often high.

Sensible loads are low
Humidity loads are high

75F and 50% RH= 65 grains/lb

Ventilation Latent Loads @ 80 cfm


Daily Latent Load @ 80 cfm (Pints/Day)



80 cfm, splitting the difference for >4 story multi-family building.

Phius CORE Ventilation Requirements			
Single or Multi-family <4		Exhaust*	Supply**
# Bedrms (Nbr)	# Baths	Design cfm	Design cfm
1	1	45	30
2	1	45	45
2	2	65	45
3	2	65	60
Multi-family >4 floors			
# Bedrms (Nbr)	# Baths	Exhaust***	Supply**
1	1	70	30
2	1	70	45
2	2	90	45
3	2	90	45

Frequency and Amount of Load @ 80 cfm




High Performing Envelopes



TOKYO



SAPPORO




Load Convergence
Across Climate Zones




AUSTIN



BOSTON



Sayo Okada,
AIA, CPHC




視覚用立面図 1/100


IMAGE: OHASHI ARCHITECTURE OFFICE



Building Load Totals




WUFI vs Man J Load Comparison




WUFI vs Man J Load Comparison

Cooling Load Comparison Btu/h/ft²



Less Δ Between Heating and Cooling Loads

HEATING & PARTIAL COOLING LOAD DISPARITY



Inputs Impacting Loads

Load Input	Default Might Be...	Problem
Window Specs- SHGC	0.39 for CZ 5A 90.1-2022 for 10-40% window-wall	Even cold climate projects with low sensible loads, higher occupancy density, little to no shading need lower SHGC
Occupancy	Fire Code Prescribed	
Schedules	Based on Max Use, Worst Case or Your Last Project	
Ventilation Rates	2-3 times higher than necessary	
Internal Loads	Office 90.1-2022 1.1 W/ft ²	

Check with Galen and James for an EIS or
e+ multi-family load

I LOVE Magic Tricks But...



Unless your ERV has a Recirculation mode that is operating on demand not just for defrost, they do not move conditioned air into rooms with closed doors. This can be a BIG comfort problem in bedrooms and especially in humid climates.

Heat Recovery VRF Systems...



Might be the right choice for your project. For example, when you have applications where it is required to have centralized systems that can provide heating and cooling at the same time. However, this is comfort choice NOT an efficiency choice. It is important to commission operating parameters to limit certain modes of operation as much as possible in partial load conditions.

DISCUSSION/ QUESTIONS



DHW Phius Basics




Hot Water in Multi-Family

Agenda


1. Is Hot Water Heating Energy a Big Deal?
2. Heating Energy, Recirculation Energy, and Parasitic Loads
3. Multi-Family Heat Pump Strategies – Central vs. Distributed
4. Sizing and Piping Network Design Considerations
5. Heat Recovery Opportunities

Hot Water in Multi-Family in the North East

Typical MF Building in the NE




Passive Building



Does Heating DHW with Heat Pumps Reduce Carbon?


- Gas Primary Energy Factor = 1.05
- Electricity Primary Energy Factor = 2.8



Does Heating DHW with Heat Pumps Reduce Carbon?

Primary Energy for 100 kBTU of Hot Water Heating

- Gas Primary Energy Factor = 1.05
- Electricity Primary Energy Factor = 1.73




2050 Comparison – Cleaner Grid

HEAT PUMPS




Contributions to HW Heating Energy





Contributions to HW Heating Energy




How to Reduce Water Heating Energy:

- Reduce Consumption - (Low flow)
- Use Waste Heat - (Heat Recovery)
- Efficient Generation - (Heat Pumps)
- Free Heat - (Solar HW)



Contributions to HW Heating Energy




How to Reduce Recirculation Losses:

- Eliminate Recirculation - (Distributed Generation)
- Reduce Length of Recirculation - (Layout)
- Demand Based Controls
- More Pipe Insulation
- Efficient Generation - (Heat Pumps)
- Free Heat - (Solar HW)



Contributions to HW Heating Energy





How to Reduce Standing:

- More Insulation
- Store Less Water - (Central or Semi-Central)
- Efficient Generation - (Heat Pumps)
- Free Heat - (Solar HW)



Pump Energy

- Eliminate Recirculation
- Demand Based Controls
- Less Pipe Friction
- Efficient Pumping

Smart Architectural Layout



2x DCW, DHW & SAN



Be Smart!

DHW Sizing | Actual Loads >40% Less

HW heaters are oversized based on outdated assumptions for fixture flow, and occupant diversity.

Example:

- 60 occupant apartment building
- Standard ASHRAE assumptions:
 - 210 gallons storage
 - 82,000 BTU/HR heater
- Adjusted for modern fixtures and Diversity:
 - 110 gallons storage
 - 41,000 BTU/HR heater





Table 1. Demographic Characteristics Correlation to DHW Consumption


Demographic Characteristics	LMH Factor
No occupants work Public assistance & low income (mix) Family & 1 parent households (mix) High % of Children Low income	HIGH
Families Public assistance Singles 1 parent households	MEDIUM
Couples Higher population density Middle income Seniors One person works, 1 stays home All occupants work	LOW

ASHRAE Usage Profile Chart



Adapted from ASHRAE Handbook

HW Consumption Measured Data



**MEASURED USE PEAK
LOWER THEN DESIGN**

HW Consumption Study for 95 unit Senior Housing apartment building.



	Range (GPM)	Duration (Minutes/day)	%	Cumulative Flow (Gallons)
Low Draw	0-3	1152	80%	1,400
Med Draw	3-6	230	16%	280
High Draw	6-9	43	3%	53
Peak Draw	9+	14	1%	18

Total Gallons per day				1,750
-----------------------	--	--	--	-------



HW Consumption Measured Data

HW Consumption Study
for 99 unit Senior
Housing apartment
building in NY.



Colonial I monitoring study. Courtesy of P. Skinner & G. Klein.

More Data

Figure 2. Daily Load Shape - Water Heater
source: LBL-PG&E






Figure 16. Measured DHW load profiles by month.




THREE – 199,000 BTU/HR GAS
TANKLESS HW HEATERS
TOTAL CAPACITY: 597,000 BTU/HR
TOTAL HEATER COST: ~\$6,000



FOUR – 15,000 BTU/HR HEAT
PUMP HW HEATERS
TOTAL CAPACITY: 60,000 BTU/HR
TOTAL HEATER COST: ~\$18,000

DHW Design and Layout



Water Demand Calculator (WDC v2.1)

PROJECT NAME :

Click for Drop-down Menu →

Total Number of Apartments in the Building →

Total Apartments in this Calculation →

Monday, October 11, 2021
4:49 PM

FIXTURE GROUPS		FIXTURE	ENTER TOTAL NUMBER OF FIXTURES	PROBABILITY OF USE (%)	ENTER FIXTURE FLOW RATE (GPM)	MAXIMUM RECOMMENDED FIXTURE FLOW RATE (GPM)
Bathroom Fixtures	1	Bathtub (no Shower)	0	0.38	5.5	5.5
	2	Bidet	0	0.55	2.0	2.0
	3	Combination Bath/Shower	0	1.41	5.5	5.5
	4	Faucet, Lavatory	95	1.11	1.5	1.5
	5	Shower, per head (no Bathtub)	95	0.94	2.0	2.0
	6	Water Closet, 1.28 GPF Gravity Tank	95	0.55	3.0	3.0
Kitchen Fixtures	7	Dishwasher	0	0.32	1.3	1.3
	8	Faucet, Kitchen Sink	95	1.11	2.2	2.2
Laundry Room Fixtures	9	Clothes Washer	5	1.33	3.5	3.5
	10	Faucet, Laundry	0	1.11	2.0	2.0
Bar/Prep Fixtures	11	Faucet, Bar Sink	0	1.11	1.5	1.5
Other Fixtures	12	Fixture 1	0	0.00	0.0	6.0
	13	Fixture 2	0	0.00	0.0	6.0
	14	Fixture 3	0	0.00	0.0	6.0

COMPUTED RESULTS FOR PEAK PERIOD CONDITIONS

Total No. of Fixtures in Calculation
n = 385

99th Percentile Demand Flow
Q = 17.0 GPM

Hunter Number
H(n,p) = 3.59

Stagnation Probability
Pr[Zero Demand] = 3%

DOWNLOAD RESULT

RESET WDC

↓ Select Units for Water Demand ↓



GPM LPM LPS

RUN WDC

System Types



Central vs. Distributed?



Distributed Heat Pumps

One heater per apartment

PROS

No Re-Circ Losses

Lower Piping Cost

May Work Well in Some Buildings


CONS

Sound can be an Issue in Small Apartments

Expensive

More Stand-by losses

Heat load on apartment –
Compressors in Series



Distributed Heat Pumps

One heater serves multiple apartments

PROS

No Re-Circ Losses

Lower Piping Cost

Easy heat recovery
in the Cooling
Season


Water Heating
Redundancy -
Resiliency

CONS

Space for Heaters



More Equipment to
Maintain

Can be a challenge to
manage heat pump air



Distributed Heat Pumps

One heater serves multiple apartments



Central Heat Pump Systems

PROS

Ease of Maintenance
/ Less EQ

Heat Recovery
Possible with Central
HVAC

CO2 Based EQ
Available

Takes up Less Space

Doesn't add to
Building Heating Load

CONS


Re-Circ Losses

Less Redundancy /
Resiliency

More Complex

Central System Design:

- Minimize time to service
- Don't over-size piping network
- Proper HW heater sizing




DISCUSSION/ QUESTIONS





HVAC Loads and System Deep Dive -
Galen Lead, James make additions at the end



GALEN STAENGL, PE, CPHC, LEED AP



Graph from 'Natural Capitalism' by Paul Hawkins, Amory Lovins, and L. Hunter Lovins




Life Cycle Cost Minimum

Can We Eliminate a System – Heating?



Can we heat it
with a hair dryer?



$1200 \text{ sqft} \times 3.14 \text{ BTU/sqft h} = 3,768 \text{ BTU/hr} = 1,100 \text{ W} \rightarrow \text{YES!}$

$86 \text{ cfm} * 1.08 * 40 = 3,715 \text{ BTU/hr}$

Climate in Germany


TEMPERATURE RANGE Adaptive Comfort

LOCATION: **FRANKFURT AM MAIN, -, DEU**
 Latitude/Longitude: 50.05° North, 8.6° East, Time Zone from Greenwich 1
 Data Source: IVEC Data 106370 WMO Station Number, Elevation 370 ft

LEGEND

- RECORDED HIGH - ○
- DESIGN HIGH -
- AVERAGE HIGH -
- MEAN -
- AVERAGE LOW -
- DESIGN LOW -
- RECORDED LOW - ○
- COMFORT ZONE -
- (Acceptability Limits 90%)


- DESIGN HIGH: Residential
- 1% of Hours Above
 - .5% of Hours Above
 - 0% of Hours Above
- DESIGN LOW: Residential
- 1% of Hours Below
 - .5% of Hours Below
 - 0% of Hours Below
- TEMPERATURE RANGE:
- 10 to 110 °F
 - Fit to Data




76
Compressor
Cooling Hours

Can We Eliminate a System – Cooling?


- Internal gains limit the cooling size reduction
- Latent loads must be treated
- Multi-family presents a special challenge




Loads for a Dorm in Virginia




Loads for a Dorm in Virginia




Loads for a Dorm in Virginia




Loads for a Dorm in Virginia




Loads for a Dorm in Virginia




Loads for a Dorm in Virginia




Loads for a Dorm in Virginia




Loads for a Dorm in Virginia




Loads for a Dorm in Virginia




Loads for a Dorm in Virginia




Loads for a Dorm in Virginia



Loads for a Dorm in Virginia






Right-Sized Equipment


Lower First Cost - Lower Energy Cost - Better Humidity Control

2 Units,
17,100
BTU/hr
unit
serves
350 sqft
~ 245
sqft/ton



Standard

367
sqft/ton
HVAC
Cost:
~\$20 /
sqft



Passive House Building

1,400
sqft/ton
HVAC Cost:
~\$11 / sqft

1 - 6,000
BTU/hr unit
serves 350
sqft ~ 700
sqft/ton


Low Static Pressure Design

Less ductwork / low static pressure design.




Lower First Cost - Lower Energy Cost

Unnecessary Ductwork




Standard




Passive House Building

Passive Envelope eliminates need to heat at the perimeter

The Load Shift




Advantageous for Ventilation System (Or Cooling System) to Economize!



ERV BYPASSES CORE TO ALLOW COOL FRESH AIR COOLS ROOMS DIRECTLY

Ventilation System Climate Considerations

Typical Multi-Family Moisture Rates [%]



Much lower in a
Passive House!

Humidity sources
dominated by
ventilation load,
which varies greatly
by climate




Define Loads – Envelope Loads

Energy Demands with Reference to the Treated Floor Area				
Treated Floor Area:	7243	ft ²		
	Applied:	Monthly Method	PH Certificate:	Fulfilled?
Specific Space Heat Demand:	4.43	kBTU/(ft²yr)	4.75 kBTU/(ft²yr)	Yes
Pressurization Test Result:	0.60	ACH₅₀	0.6 ACH ₅₀	Yes
Specific Primary Energy Demand (DHW, Heating, Cooling, Auxiliary and Household Electricity):	27.2	kBTU/(ft²yr)	38.0 kBTU/(ft ² yr)	Yes
Specific Primary Energy Demand (DHW, Heating and Auxiliary Electricity):	7.0	kBTU/(ft²yr)		
Specific Primary Energy Demand Energy Conservation by Solar Electricity:		kBTU/(ft²yr)		
Heating Load:	4.30	BTU/(ft²hr)		

In Multi-Family Passive House, Cooling Loads are Dominated by Internal Gains!

Spec




Define Loads – Internal Loads

- In Multi-Family Passive House in Cooling Climates, internal loads determine equipment sizing
- The same is true for higher density commercial building types
- In these buildings, only a small amount of solar gain is useful.

Define Loads – Occupancy Loads & Profiles

	2	3	4	5	6	7	8	9	10	11
	Utilization Pattern		Periods of Utilization and Operation	Begin Utilization [hr]	End Utilization [hr]	Daily Utilization Hours [hr/day]	Annual Utilization Days [day/yr]	Annual Utilization Hours [hr/yr]	Annual Utilization Hours During Daytime [hr/yr]	Annual Utilization Hours During Nighttime [hr/yr]
1	Sanctuary			18	22	4	55	220	1	219
2	Merkaz			5	22	17	300	5100	3604	1496
3	Office			7	18	11	300	3300	3171	129
4	Conference			8	10	2	65	130	130	0
5	WIC			8	10	2	65	130	130	0
6	Baths			8	10	2	365	730	730	0
7	Kitchen			16	20	4	55	220	111	109

- A good understanding of building use profiles allows proper estimation of diversity, and can help point to cost effective system strategies.





Define Loads

Detailed Equipment Loads



Define Loads

Detailed Equipment Loads

Room	Area (ft ²)	Loads	Load Consumption	UOM	ASHRAE Heat Gain (btuh)		1	2	3
					Rated	Standby			
Kitchen / LR	700	Refrigerator	295	watts/hr		1008	0.25	0.25	0.25
		Dishwasher	32	watts/hr	1302		0	0	0
		Electric Oven	55	watts/hr	8189		0	0	0
		Range - Induction	112	watts/hr	9167		0	0	0
		Microwave	67	watts/hr	10900		0	0	0
		Toaster	33	watts/hr	18080		0	0	0
		Coffee Maker	4	watts/hr	3413	0	0	0	0
		Range Hood Fan	4	watts/hr	341	0	0	0	0
		Computer	15	watts/hr	222	15	0	0	0
		Printer	4	watts/hr	61	14	0	0	0
		Monitor	5	watts/hr	92	3	0	0	0
		Modem\Router\DVR	40	watts/hr	0	136	1	1	1
		TV	8	watts/hr	92	10	0	0	0
		Max Load		2.90 w/sqft			12	12	12
		Max Load	2.03	kW	Schedule %	0.6%	0.6%	0.6%	

Define Loads

Detailed Equipment Loads







Figure 4. Daily Load Shape - Cooking
source: LBL-PG&E





Load Diversity



MF Load Calculation Example

- 2 BR Apartment in Massachusetts – 937 Sq.Ft.
- Low Income – Family Housing
- SW/SE Exposure



Baseline Building Loads

COOLING

	Baseline	Unit	Load (BTU/hr)	
			Sensible	Latent
Lighting	0.6	W/sqft	1,919	-
Appliances (Manual J)			1,200	240
People	3		735	465
Ventilation	45	cfm	713	576
Infiltration	86	cfm	1,358	1,097
Solar Gain			7,719	
Conduction Gain			1,729	
TOTAL COOLING			15,373	2,378

HEATING

	Baseline	Unit	Load (BTU/hr)	
			Sensible	Latent
Lighting	0.6	W/sqft		
Appliances (Manual J)				
People	3			
Ventilation	45	cfm	3,262	
Infiltration	86	cfm	6,231	
Solar Gain				
Conduction Gain			9,874	
TOTAL HEATING			19,367	-

Looks like a 2 ton indoor unit! -
Driven by heating loads.



Phius Building Loads

COOLING

	Phius	Unit	Load (BTU/hr)	
			Sensible	Latent
Lighting	0.38	W/sqft	1,215	-
Appliances (Manual J)			1,200	240
People	3		735	465
Ventilation	45	cfm		
Infiltration	18	cfm	282	228
Solar Gain			5,428	
Conduction Gain			1,057	
TOTAL COOLING			9,917	933

HEATING

	Phius	Unit	Load (BTU/hr)	
			Sensible	Latent
Lighting	0.38	W/sqft		
Appliances (Manual J)				
People	3			
Ventilation	45	cfm		
Infiltration	18	cfm	1,246	
Solar Gain				
Conduction Gain			5,517	
TOTAL HEATING			6,763	-

1 ton indoor unit? - Cooling design capacity is 2x heating load.

Can we get to 9,000 BTU/hr?



Load Calculations

2022-11-17 LEE FORT TERRACE_v1.0 - Basis of Design_v1.7 - Excel

File Home Insert Page Layout Formulas Data Review View Automate Help

Clipboard Font Alignment Number Styles Cells Editing

AutoSave Off

Search

Input Fill Normal 2 Note 2 Normal Bad

Good Neutral Calculation Check Cell Explanatory ...

AutoSum Fill Clear Sort Filter

Figures based on 2018 IMC, ASHRAE 62.1-2016, and ASHRAE 55-2010

Select Load to Evaluate

Client: Icon Architecture

Project: LeeFort Terrace

Location: Salem, MA

Date: 2022-11-17

Author: Jonathan Nilsen

Editor: New Version

System: VRF System

Select Visible Columns

All Columns

Select Code

IMC

Add Projected Temperature Rise

Projected Temperature Rise (°F): 4.5 F

Relative Humidity: 60%

Summer Outdoor Temperature (°F): 89.4 F

Winter Outdoor Temperature (°F): 4.1 F

Dehumidification Air Humidity Ratio (grains/lb): 121.60

Cooling Supply Temperature: 50 F

Heating Supply Temperature: 95 F

Cooling Setpoint: 75 F

Heating Setpoint: 70 F

ERV-1: 72% 5,200 CFM 5,285 CFM 759 kBtu/h 416 kBtu/h

ERV-2: 62% 3,710 CFM 3,450 CFM 670 kBtu/h 364 kBtu/h

ERV-3: 72% 70 CFM 70 CFM 10 kBtu/h 10 kBtu/h

ERV-4: 58% 560 CFM 560 CFM 12 kBtu/h 20 kBtu/h

ERV-5: 75% 0 CFM 0 CFM 0 kBtu/h 0 kBtu/h

ERV-6: 80% 0 CFM 0 CFM 0 kBtu/h 0 kBtu/h

ERV-7: 85% 0 CFM 0 CFM 0 kBtu/h 0 kBtu/h

Overheat Protection Setpoint: 85 F

Freeze Protection Setpoint: 55 F

ERV Summer Effectiveness (%): 68

ERV Winter Effectiveness (%): 70

ERV Summer LPC (%): 72

ERV Outside Airflow (CFM): 74

ERV Exhaust Airflow (CFM): 75

ERV Cooling Load (kBtu/h): 76

ERV Heating Load (kBtu/h): 77

None 0.0

ASHRAE 62.1-2016 Table 6.2

ASHRAE 55-2010 Table 5.4

OA per person (cfm/person)

OA per Area (cfm/ft²)

OA Required (cfm)

Level	Zone	ERV	Space Number	Space Name	Room Particulars	Space Type	Unit Type	Area (ft²)	Number of Bathrooms/Storage	Conditioned?	Cooling Setpoint (°F)	ERV Summer Supply (CFM)	ERV Dehum Supply (CFM)	Heating Setpoint (°F)	ERV Winter Supply (CFM)	Occupiable?	Area per Person	Number of People	ASHRAE 62.1-2016 Table 6.2	ASHRAE 55-2010 Table 5.4	OA per person (cfm/person)	OA per Area (cfm/ft²)	OA Required (cfm)
15	Garage	CENTRAL	None	U-001	001 - UTILITY	Public Spaces - Electrical/Mechanical Room	Common	533	0	Fully Conditioned	75	89.4	80.3	70	4.1	No	0	0	CS	1.0	0	0	0
16	Garage	CENTRAL	None	A-002-1	002 - BIKE ROOM	Storage - Active	Common	481	0	Fully Conditioned	75	89.4	80.3	70	4.1	No	0	0	CS	1.0	0	0	0
17	Garage	CENTRAL	None	V-002	3 - VESTIBULE WEST	Public Spaces - Corridors	Common	96	0	Fully Conditioned	75	89.4	80.3	70	4.1	No	0	0	CS	1.0	0	0.06	6
18	Garage	CENTRAL	ERV-1	C-102	004 - LOBBY	Offices - Main Entry/Lobbies	Common	621	0	Fully Conditioned	75	79.0	76.5	70	45.6	Yes	100.00	7	CS	1.0	5.0	0.06	72
19	Garage	CENTRAL	None	V-001	4 - VESTIBULE CENTRAL	Public Spaces - Corridors	Common	76	0	Fully Conditioned	75	89.4	80.3	70	4.1	No	0	0	CS	1.0	0	0.06	5
20	Garage	CENTRAL	ERV-1	C-103	006 - STORAGE	Storage - Inactive	Common	91	0	Fully Conditioned	75	79.0	76.5	70	45.6	No	0	0	CS	1.0	0	0	0
21	Garage	CENTRAL	ERV-1	C-001	007 - CORRIDOR	Public Spaces - Corridors	Common	359	0	Fully Conditioned	75	79.0	76.5	70	45.6	No	0	0	CS	1.0	0	0.06	22
22	Garage	CENTRAL	ERV-1	A-002	008 - FITNESS	Recreation and Amusement - Health Club/Aerobics Facility	Common	809	0	Fully Conditioned	75	79.0	76.5	70	45.6	Yes	25.00	6	CS	1.0	20.0	0.06	169
23	Garage	CENTRAL	ERV-1	WC-001	009 - WC	Public Spaces - Toilet Rooms-Public	Common	61	1	Fully Conditioned	75	79.0	76.5	70	45.6	No	0	0	CS	1.0	0	0	0
24	Garage	CENTRAL	ERV-1	A-003	010 - COMMUNITY ROOM	Offices - Conference Rooms	Common	1,034	0	Fully Conditioned	75	79.0	76.5	70	45.6	Yes	20.00	40	CS	1.0	5.0	0.06	262
25	Garage	CENTRAL	ERV-1	ST-002	011 - STORAGE	Storage - Inactive	Common	87	0	Fully Conditioned	75	79.0	76.5	70	45.6	No	0	0	CS	1.0	0	0	0
26	Garage	CENTRAL	None	V-003	5 - VESTIBULE EAST	Public Spaces - Corridors	Common	95	0	Fully Conditioned	75	89.4	80.3	70	4.1	No	0	0	CS	1.0	0	0.06	6
27	Garage	CENTRAL	ERV-4	TR-001	013 - TRASH	Storage - Janitor, Trash Rooms	Common	556	0	Fully Conditioned	75	81.0	77.2	70	46.3	No	0	0	CS	1.0	0	0	0
28	Garage	CENTRAL	None	W-001	014 - WATER	Public Spaces - Electrical/Mechanical Room	Common	684	0	Fully Conditioned	75	89.4	80.3	70	4.1	No	0	0	CS	1.0	0	0	0
29	Garage	CENTRAL	ERV-3	U-002	MAINTENANCE SHOP	Offices - Office Spaces, Open Plan	Common	552	0	Fully Conditioned	75	79.0	76.5	70	46.9	Yes	200.00	3	CS	1.0	5.0	0.06	48
30	Garage	CENTRAL	ERV-3	ST-006	016 - WC	Public Spaces - Toilet Rooms-Public	Common	69	1	Fully Conditioned	75	79.0	76.5	70	46.9	No	0	0	CS	1.0	0	0	0
31	Garage	CENTRAL	ERV-3	ST-003	017 - PRIVATE OFFICE	Offices - Office Spaces, Enclosed	Common	186	0	Fully Conditioned	75	79.0	76.5	70	46.9	Yes	200.00	1	CS	1.0	5.0	0.06	16
32	Level 1	LOWER WEST	ERV-1	101	101 - 2B.1	Offices - Living Areas/Bedroom, with Bathroom	2B.1	937	1	Fully Conditioned	75	79.0	76.5	70	45.6	Yes	500.00	3	CS	1.0	15.0	0	45
33	Level 1	LOWER WEST	ERV-1	102	102 - 2B.1	Offices - Living Areas/Bedroom, with Bathroom	2B.1	984	1	Fully Conditioned	75	79.0	76.5	70	45.6	Yes	500.00	3	CS	1.0	15.0	0	45
34	Level 1	LOWER WEST	ERV-1	103	103 - 1A.1	Offices - Living Areas/Bedroom, with Bathroom	1A.1	704	1	Fully Conditioned	75	79.0	76.5	70	45.6	Yes	500.00	2	CS	1.0	15.0	0	30
35	Level 1	LOWER WEST	ERV-1	104	104 - 1A.1	Offices - Living Areas/Bedroom, with Bathroom	1A.1	700	1	Fully Conditioned	75	79.0	76.5	70	45.6	Yes	500.00	2	CS	1.0	15.0	0	30
36	Level 1	LOWER WEST	ERV-1	105	105 - 1A	Offices - Living Areas/Bedroom, with Bathroom	1A	687	1	Fully Conditioned	75	79.0	76.5	70	45.6	Yes	500.00	2	CS	1.0	15.0	0	30
37	Level 1	LOWER WEST	ERV-1	106	106 - 1A	Offices - Living Areas/Bedroom, with Bathroom	1A	682	1	Fully Conditioned	75	79.0	76.5	70	45.6	Yes	500.00	2	CS	1.0	15.0	0	30
38	Level 1	LOWER WEST	ERV-1	107	107 - 1C	Offices - Living Areas/Bedroom, with Bathroom	1C	694	1	Fully Conditioned	75	79.0	76.5	70	45.6	Yes	500.00	2	CS	1.0	15.0	0	30
39	Level 1	LOWER WEST	ERV-1	108	108 - 2C	Offices - Living Areas/Bedroom, with Bathroom	2C	885	1	Fully Conditioned	75	79.0	76.5	70	45.6	Yes	500.00	3	CS	1.0	15.0	0	45
40	Level 1	LOWER WEST	ERV-1	109	109 - 1E BF	Offices - Living Areas/Bedroom, with Bathroom	1A, ADA	691	1	Fully Conditioned	75	79.0	76.5	70	45.6	Yes	500.00	2	CS	1.0	15.0	0	30
41	Level 1	LOWER WEST	ERV-1	C-100C	018 - CORRIDOR WEST	Public Spaces - Corridors	Common	595	0	Fully Conditioned	75	79.0	76.5	70	45.6	No	0	0	CS	1.0	0	0.06	36
42	Level 1	CENTRAL	ERV-1	LL-101	111 - LIVING LOUNGE	Offices - Office Spaces, Open Plan	Common	622	0	Fully Conditioned	75	79.0	76.5	70	45.6	Yes	200.00	4	CS	1.0	5.0	0.06	57
43	Level 1	CENTRAL	ERV-1	A-101-1	COMPUTER LOUNGE	Offices - Office Spaces, Open Plan	Common	740	0	Fully Conditioned	75	79.0	76.5	70	45.6	Yes	200.00	4	CS	1.0	5.0	0.06	64
44	Level 1	CENTRAL	ERV-1	113	113 - 1A	Offices - Living Areas/Bedroom, with Bathroom	1A	691	1	Fully Conditioned	75	79.0	76.5	70	45.6	Yes	500.00	2	CS	1.0	15.0	0	30
45	Level 1	CENTRAL	ERV-1	QR-101	114 - QR.1	Offices - Office Spaces, Enclosed	Common	83	0	Fully Conditioned	75	79.0	76.5	70	45.6	Yes	200.00	1	CS	1.0	5.0	0.06	10
46	Level 1	CENTRAL	ERV-1	115	115 - 1E BF	Offices - Living Areas/Bedroom, with Bathroom	1A, ADA	692	1	Fully Conditioned	75	79.0	76.5	70	45.6	Yes	500.00	2	CS	1.0	15.0	0	30
47	Level 1	CENTRAL	ERV-1	QR-102	116 - QR.2	Offices - Office Spaces, Enclosed	Common	80	0	Fully Conditioned	75	79.0	76.5	70	45.6	Yes	200.00	1	CS	1.0	5.0	0.06	10
48	Level 1	CENTRAL	ERV-1	117	117 - 2D	Offices - Living Areas/Bedroom, with Bathroom	2D	891	1	Fully Conditioned	75	79.0	76.5	70	45.6	Yes	500.00	3	CS	1.0	15.0	0	45
49	Level 1	CENTRAL	ERV-1	118	118 - 2A	Offices - Living Areas/Bedroom, with Bathroom	2A	949	1	Fully Conditioned	75	79.0	76.5	70	45.6	Yes	500.00	3	CS	1.0	15.0	0	45
50	Level 1	CENTRAL	ERV-2	119	119 - 2A	Offices - Living Areas/Bedroom, with Bathroom	2A	949	1	Fully Conditioned	75	80.5	77.0	70	46.9	Yes	500.00	3	CS	1.0	15.0	0	45
51	Level 1	CENTRAL	ERV-1	L-101	120 - LAUNDRY	Cleaners, Laundries - Coin-Operated Laundries	Common	205	3	Fully Conditioned	75	79.0	76.5	70	45.6	Yes	50.00	1	CS	1.0	7.5	0.12	32
52	Level 1	LOWER EAST	ERV-2	121	121 - 2A	Offices - Living Areas/Bedroom, with Bathroom	2A	945	1	Fully Conditioned	75	80.5	77.0	70	46.9	Yes	500.00	3	CS	1.0	15.0	0	45
53	Level 1	LOWER EAST	ERV-2	122	122 - 3C	Offices - Living Areas/Bedroom, with Bathroom	3C	1,135	2	Fully Conditioned	75	80.5	77.0	70	46.9	Yes	500.00	4	CS	1.0	15.0	0	60

Electrification – Space Heat / Cool

Air-to-Air



Air-to-Water



Water-to-




Water-to-Water



Electrification - DHW



Mechanical Pod Development



Hydronic piping run behind cladding

Air to water HP and fluid cooler

DHW generated from rooftop equipment and distributed through existing piping if in good condition [Heat Recovery]


Exhaust

Fresh Air

ERV

WS HP

Indoor Pod



TKF



DISCUSSION/ QUESTIONS



DHW Deep Dive - James lead, Galen
make additions at end

DHW is a tough nut
to crack- here's what
we know.

Cost of Energy

Electricity:

- Total cost in January: \$5,060.29
- Total kWh use: 22200 kWh



\$0.28/kWh

Gas:

- Total cost in January: \$5,542.46
- Total therm use: 3996 therms
 - \$1.39/therm




\$0.05/kWh


Electricity is 5.6 x more expensive than gas

Individual Heaters vs Central Water Plant

Individual Water Heaters



Central Plant



Individual Heaters

Issues with local water heaters

- Take up space

Hybrid heat pump issues

- Heat pumps in series
- Cold draft
- Better suited for commercial kitchens




There is no individual DHW solution that has a low operating cost.


Central Plant

- CO_2 based
- **High upfront and operating cost compared to central gas plant**
- Chance for COP 2-3
- High temperature
- Low recovery/high storage
- New to market

Electric ASHP Domestic Hot Water Central System



Heat Capacity Water vs Air




Heat capacity is the measure of energy required to raise a quantity of a substance by one temperature degree. Heat capacities for water and air:

$$\text{Water: } 1 \frac{\text{BTU}}{\text{lb} \cdot \text{F}}$$

$$\text{Air: } 0.24 \frac{\text{BTU}}{\text{lb} \cdot \text{F}}$$

The energy required to heat water is 4 x that of air! Therefore with a hybrid heat pump we need to move a lot of air.

Heat Capacity Comparison



Water has the highest heat capacity of any common substance!

Seasonal Water Temperature – MWRA





Figure 2-1. Comparison of 2020 (solid red line) surface water temperature (°C) at Buoy 44013 (“Boston Buoy”) in the vicinity of the nearfield with 1989-2019 (cyan lines). The vertical dashed lines are when the 10 surveys were conducted in 2020.

Seasonal Water Temperature – Mass Save Guidelines



Hybrid Heat Pump
Water Heaters =
Cold Drafts

Summer Condition - What amount of energy is required to heat 20 gallons from 70°F to 125°F?

(Gallons) x (Temperature Difference) x (Specific Heat) x (Pounds/Gallon) = Energy

$$(20 \text{ gals}) \times (125^{\circ}\text{F} - 70^{\circ}\text{F } \Delta T) \times \left(1 \frac{\text{BTU}}{\text{lb} \cdot \text{F}}\right) \times \left(8.33 \frac{\text{lb}}{\text{gal}}\right) = 9,163 \text{ BTUs}$$

Summer Condition - What amount of energy is extracted from the apartment.

Total energy to heat the water: ***9,163 BTUs***

Portion of energy from electricity = $(1/3) \times 9,163 = 3,054 \text{ BTUs}$

Portion of energy from apartment = $(2/3) \times 9,163 = 6,109 \text{ BTUs}$

Assumes a COP of 3 water heater efficiency

Summer Condition - What is the HPWH run time when we heat 20 gallons from 70°F to 125 °F?

Assumptions:

1. 70 degrees F entering air temperature (EAT)
2. 55 degrees F leaving air temperature (LAT)
3. 9,163 BTUs moved from air to water

4. ~~200 CFM water heater fan volume~~ ^{Energy} = Time
[(Volume/Time) x (Temperature Difference) x (Specific Heat) x (Density)] *9,163 BTUs*

$$\frac{(200 \frac{ft^3}{min}) \times (70 \text{ }^\circ F - 55 \text{ }^\circ F) \times (0.24 \frac{BTU}{lb \cdot F}) \times (0.075 \frac{lb}{ft^3})}{9,163 \text{ BTUs}} = 170 \text{ minutes}$$

Almost 3 hours!

Conclusion: A significant cold draft of 200 CFM and 55°F is discharged into the apartment for 170 minutes. An uncontrolled source of cold air is likely to cause occupant comfort issues.




Cooling Load Study

- One bedroom, 700 SF, apartment with an Eastern exposure
- Peak cooling load with Boston design conditions: 7,000 Btu/hr
- Amount of cooling contributed by the water heater: 6,100 Btu/hr

$$\frac{6,100 \text{ Btu/hr}}{7,000 \text{ Btu/hr}} = 87\%$$

DHW cold draft is almost equal to summer time peak AC load!

Heat pump water heater will overcool even in the summer.



Winter Condition - Temperature Difference Water vs Air

The temperature difference for water is significantly greater than air

Water: 45°F → 125°F

Air: 70°F → 55°F

**We are increasing water temperatures
more than 5x more than we are
decreasing the air temperature.
5-1/3 in this case.**



Winter Condition - Quantity of Water vs Air

$$(200 \frac{ft^3}{min}) \times (246 mins^1) \times (0.075 \frac{lb}{ft^3}) = 3,690 lbs \text{ of air}$$

$$(20 gals^2) \times (8.33 \frac{lb}{gal}) = 167 lbs \text{ of water}$$

Due to the 4x difference in heat capacity plus the 5.3x difference in temperature difference we need to move a lot of air to extract the heat needed for hot water production. And it's going to be cold (55°F).

BTW 200 CFM is 2.1 air changes/hr for a 700 SF apartment.

Also, we are moving 49,200 cubic feet of cold air.


1: In the winter condition the temperature rise is from 45°F to 125 °F

2: 20 gallons of 125 °F water equates to approximately 30 gallons of hot water out of the faucet



Heat Pumps in Series

Two Heat Pumps in Series



COP is the ratio of useful heating provided to the energy required.

For a COP_1 of 3, the ASHP uses 1 unit of energy that is electricity powering the compressor to move 2 units of heat from the outdoors. This results in 3 units of heat delivered to the corridor.

For a HPWH with a COP_2 of 3, all 3 units of the heat moved by the ASHP are utilized by the HPWH.

The HPWH uses 1.5 units of energy that is electricity powering the compressor to move the 3 units of heat from the corridor. This results in 4.5 units of heat delivered to hot water.

The total COP for this system would be the heat output 4.5 divided by the energy input, 2.5, which equals 1.8.

Heat Pumps in Series Math Steps

$$O_x = E_x + I_x \quad (1)$$

Where, O = heat output of system, E = electricity used in the process, I = energy extracted from an outside medium.

$$COP_x = \frac{O_x}{E_x} \quad (2)$$

The entire output by heat pump 1 is used as input by heat pump 2, therefore:

$$O_1 = I_2 \quad (3)$$

The total COP of the system is defined as the heat output of the last heat pump in the series divided by the total electricity used by the system to achieve that output.

$$COP_{total} = \frac{O_3}{E_1 + E_2} \quad (4)$$

Replace the numerator of Equation 4 by rearranging Equation 2.

$$COP_{total} = \frac{COP_2 E_2}{E_1 + E_2} \quad (5)$$

Replace the first term in the denominator by rearranging Equation 2.

$$COP_{total} = \frac{COP_2 E_2}{\frac{O_1}{COP_1} + E_2} \quad (6)$$

Replace O_1 with Equation 3.

$$COP_{total} = \frac{COP_2 E_2}{\frac{I_2}{COP_1} + E_2} \quad (7)$$

In order to put the I term in terms of COP and E, insert Equation 1 into Equation 2 and rearrange to solve for I:

$$COP_x = \frac{E_x + I_x}{E_x} = 1 + \frac{I_x}{E_x} \quad (8)$$

$$I_x = E_x(COP_x - 1) \quad (9)$$

Insert Equation 8 in for the I terms in Equation 6.

$$COP_{total} = \frac{COP_2 E_2}{\frac{E_2(COP_2 - 1)}{COP_1} + E_2} \quad (10)$$

Cancel out E_2 from the equation


$$COP_{total} = \frac{COP_2}{\frac{(COP_2 - 1)}{COP_1} + 1} \quad (11)$$

Multiply the numerator and denominator by COP_1

$$\boxed{COP_{total} = \frac{COP_1 COP_2}{COP_1 + COP_2 - 1}} \quad (12)$$


Plug and Chug

Looking at the original example, with a total COP of 1.8, we see the same output with this equation.




$$\frac{COP_1 COP_2}{COP_1 + COP_2 - 1} = \frac{3 * 3}{3 + 3 - 1} = 1.8$$

Graphical Representation



Number of Heat Pumps vs COP



How about some solutions?

How can we reduce electricity use in hot water heating?



Drain Water Heat Recovery

Drain Water Heat Recovery (DWHR) Definition

DWHR works by using the outgoing warm drain water to pre-heat the incoming cold fresh water




Fresh Inlet ~ 46°F

Drain Inlet ~ 101°F

Fresh Outlet ~ 75°F



Potable vs Drain Temperatures





$$\frac{\Delta T \ 25^\circ\text{F}}{\Delta T \ 57^\circ\text{F}} = 44\% \text{ Reduction}$$

**Drain water recovery
reduces the temperature we
need to raise the water by
44%!**

6 Story Midrise Stacked Bathrooms

Fresh water from DWHR to cold water supply at fixtures.

- Shower water is approximately 60% of hot water use in an apartment
- Heat required for shower water is reduced by approximately 50%
- Overall heat required for DHW is reduced by 30%




4 in. diameter, 72 in. long, 1 in. pipe connection

Cost to contractor for DWHR qty-1: \$819

For 100 unit multi-family likely need qty 8-10

Passive technology, zero electricity input, COP ∞!

DWHR Configuration When Water Heater is in Apartment




— Cold Water — Hot Water
— Pre-Heated Water — Drain Water

Power Pipe Flow Diagram

Distribution of Energy Use in PH Multi-Family

30% of DHW energy is eliminated by drain water recovery!


DWHR reduces size of ASHP DHW central plant and therefore saves first cost too!






Solar Thermal

Solar Radiation in Boston




Solar Thermal Preheating

Solar energy consumption as percentage of total consumption



21 x 200-F, SV2/SH2
 Total gross surface area: 569.63 ft²
 Azimuth: 0°
 Incl: 25°



Assumptions:

- 100 unit building
- 1.5 people per unit
- 13 gallons/day/person

Outputs:

- Qty-21 panels
- Solar panel area: 570 SF
- DHW solar fraction: 47%
- Qty-1 variable speed pump, 125 Watts max power
- Cost: \$140,000

Results of Simulation

Installed collector power:		126.39 kBtu/hr
Installed solar surface area (gross):		569.63 ft ²
Irradiation on to collector surface (active):	290.52 MMBtu	510.04 kBtu/ft ²
Energy delivered by collectors:	144.72 MMBtu	254.07 kBtu/ft ²
Energy delivered by collector loop:	143.62 MMBtu	252.15 kBtu/ft ²

DHW heating energy supply:		296.11 MMBtu
Solar contribution to DHW:		142.83 MMBtu
Energy from auxiliary heating:		160.9 MMBtu

Natural gas (H) savings:		2,165.5 therm
CO2 emissions avoided:		28,395.34 lbs
DHW solar fraction:		47.0 %
Fractional energy savings (DIN CEN/TS 12977-2):		47.6 %
System efficiency:		49.2 %

$$COP = \frac{143,000 \text{ kBtu (41,000 kWh) output}}{181 \text{ kwh input}}$$


$$COP = 227$$

Assuming 0.125 kw pump,
average 50% Watt draw, on 1/3
of the time annually

Distribution of Energy Use in PH Multi-Family

**Electricity for annual
DHW is reduced by
50%!**

**Central plant size is
not reduced because
some days we get zilch
from the sun.**






Downsizing Potable Water Piping

Case Study | Old Colony Phase 6 South Boston, MA

- 5 story multi family building
- 116,000 GSF
- 94 dwelling units




Boston Planning & Development Agency



Pipe Size Distribution – 248 CMR 10.00 vs IAPMO Water Demand Calculator

Potable Water Distribution Downsizing

248 CMR 10.00 vs IAPMO
Cold DHW CPVC and Copper Total Pipe Weights



47% weight reduction in CPVC piping – pounds saved: 876 lbs

72% weight reduction in Copper piping – pounds saved: 366 lbs

Pipe densities from: Charlotte Pipe and Foundry Company

Potable Water Distribution Downsizing

GWP¹ Reduction Using IAPMO

Reduction	Copper	CPVC	Total
kgCO ₂ e	809	2,052	2,861
%	72%	44%	50%

¹GWP (A1-A3) Data Sources: One Click LCA (Copper) & Manufacturer EPRs (CPVC)

DISCUSSION/ QUESTIONS





Multifamily MEP

Early Considerations

Layouts

HVAC

- Loads/Modeling
- Systems
 - Space-conditioning
 - Ventilation
- Ductwork


DHW

- Loads/Modeling
- Systems
- Distribution

Questions to Leave With


What is multi-family?

Building Size




Handel Architects

What is multi-family?



3BR

Apartment Size



STUDIO



YOTEL

What is multi-family?




Population



Multifamily vs. Senior Care

2012 Commercial Building Energy Consumption Survey (CBECS)





Madrone Passive House



Heating





1 BR Apartment Size: 385 sqft

Code Exhaust Rate: 45 cfm

Heating Load: 1 BR – 1,000 - 1,500 BTU/hr

Ventilation Air Heat Rate (@95 F): 1,350 BTU/hr + 1 person = 1,550 BTU/hr









Cooling

If 35% of windows open according to these rules:
 If inside temp > 72 F and
 Outside temp < inside temp


Frequency distribution



- Roof: R-45
- Walls: R-32
- Windows: U-0.23, SHGC 0.23
- Slab: uninsulated
- Operable portion of window: 35%



**COOLING THROUGH VENTILATION AIR:
 $1.08 \times 45 \text{ CFM} \times 20 \text{ F} = \sim 1,000 \text{ BTU/HR}$**





14





FIGURE 3: EXAMPLE REFRIGERANT SHAFT DETAIL

Self Contained


1. No outdoor units!
2. One piece of EQ replaces HP, ERV & Dehumidifier (maybe)
3. Low level of refrigerant
4. Integrated humidity control
5. Low installed cost
6. May need supplemental heating depending on loads and climate – electrical or additional heat pump
7. No Passive ERV core reduces energy performance



Multi-family Retrofit

Colonial II

A Net-Zero Energy Retrofit




Colonial II




Window Box A/C

Pre- Retrofit EUI: 117 kBTU/sqft!



Masonry Construction:
No Wall Insulation



Colonial II



Ancient Gas Boilers:
2 x 2.6 MMBTU/hr



Gas HW Heaters:
2 x 300kBTU/hr

Colonial II

New Windows





New Air Barrier

New Exterior Insulation



Colonial II



All-In One Heat Pump

Simple Ductwork

1 UNIT TYPE A MECHANICAL DUCTWORK PLAN
SCALE: 1/4" = 1'-0"

Interior Retrofit 99 to 74 Apartments

~1,000,000 BTU/HR OF HEAT PUMP INSTALLED

Colonial II





~0.9 W/SQFT

ASE 85%


TRE 67%



INTEGRATED HEAT PUMP WITH ERV



Colonial II




Colonial II

All-in One WS
Heat Pump



Geothermal
Manifold

Colonial II



Solar Field Above Well Field

Vertical Geothermal Well Field

Colonial II

- New electrical service – 3000 A / 208 V / 3 Phase
- Old electrical service - 1400 A / 208 V / 3 Phase





Required New Fire
Pump, and Solar Field
Required Electrical
Service Upgrade

Colonial II


HW consumption of building population measured prior to retrofit
Pre-retrofit condition:

- 99 Apartments
- Low flow fixtures




Measured HW Consumption: Courtesy of Klein and Skinner

Colonial II




HEAT PUMP
CAPACITY ~12% OF
ORIGINAL GAS
CAPACITY!

Colonial II



Ducted Range Hoods


Kitchen Pollutants



- Carbon Monoxide
- Nitrogen Oxides
- Particulates
- VOCs

Reproduced with permission from Environmental Health Perspectives

Code Requirements



Recirculating Range Hood


Most Mechanical Codes:

- 100 CFM intermittent or 25 cfm continuous

ASHRAE 62.2-2013

- 100 CFM intermittent (Vented Range Hood)

Vented Range Hoods in Passive House MF?



Recirculating Range Hood



Makeup Air Requirements for Direct Kitchen Hood Exhaust
Lisa White, September 18, 2019

- Building MUA must keep building pressurization below 5 Pa assuming 12% of hoods are operational.
- Recommend tight fitting backdraft damper or automatic damper in duct for pressure control

DISCUSSION/ QUESTIONS



Office Retrofit Case Study

4528 Freeret Street

Phius REVIVE 2024 RETROFIT STANDARD FOR BUILDINGS v0.8

Good for the planet | Good for your buildings | Quality assured results



CRITICAL UPGRADES



ROOF



**WATER
MANAGEMENT
DETAILING**



HVAC



WINDOWS



**SITE
DRAINAGE**

Roof Replacement is the #1 Priority




Bulk Water Failure



KL site images
Standing water on roof at east parapet wall may be related to areas of high moisture content and may be related to wet batts noted in BSC Report: pg 18, Figure 40

Air Leakage Failure





LaGrange Report: pg 21, Image 11163
West wall/roof interface.
Air leakage from exterior to interior while building is depressurized for infiltration testing.

Thermal Failure





BSC Report: pg 37, Figure 111
Roof 2nd floor east.
Extreme heat transfer due to very poor thermal performance. This results from solar gain of roof. Outside temperature at the time of reading was 65F.



4528 Freeret Street





4528 Freeret Street – Loads - IECC2021





4528 Freeret Street – Loads – Phius Revive





4528 Freret Street – Loads - Compared



SYSTEM OPTIONS



GEO




GEO + AS DOAs


4-PIPE

VRF

GEOHERMAL SYSTEM SCHEMATIC





GEOHERMAL SYSTEM w/ AIR SOURCE DOAs



GEOHERMAL WELLS

All Geothermal System
20 Wells (300' deep)




DESIGN SITE PLAN | 1

Geothermal plus air source
DOAs
15 wells (300' deep)

1" = 20'-0" DESIGN SITE PLAN | 1

HYDRONIC SYSTEM w/ AIR SOURCE DOAs




AIR-SOURCE DOAs WITH ENERGY RECOVERY

4-PIPE HYDRONIC FAN COILS



2 SETS OF INSULATED CIRCULATION PIPING (4-PIPE)

BUFFER TANKS WITH PUMPS

VRF SYSTEM w/ AIR SOURCE DOAs





SYSTEM COMPARISON



System	Carbon (lb Co2e/MWh Over 20 Years)	Energy	Maintenance	Installation
Geothermal plus air source DOAs	1,212,903	23.06	\$	\$\$ (\$ with tax credits)
All Geothermal	1,131,623	19.96	\$	\$\$\$ (\$ with tax credits)
Chilltrix Heat Pump	1,263,624	24.72	\$\$	\$\$
VRF	1,623,994	26.85	\$\$\$	\$

NET ZERO



~100 kW Rooftop solar array required!

DISCUSSION/ QUESTIONS



School Case Study




**Seacoast
Waldorf
Middle
School –
Elliot, ME**

Multi-Purpose Room Heating & Cooling





Classrooms with Three Exposures




Roof Assembly

TYPICAL SLOPED ROOF ASSEMBLY ON SIPs

- ASPHALT SHINGLE ROOFING
- HIGH PERFORMANCE WATERPROOF UNDERLAYMENT
- SIP ROOF PANELS
- ROOF TRUSSES - REFER TO STRUCTURAL DRAWINGS
- 2x4 EXTENSION, ALIGN WITH FRAMING, ATTACH THROUGH INSUL. TO SOLID FRAMING, CONTINUE ROOF SHEATHING OVER EXTENSIONS.
- CONT. 12" WIDE STRIP OF ICE & WATER SHIELD OVER DRIP EDGE (TYP)


- CONT. 2X SUB FASCIA
- 1x CONT. FASCIA
- 1x6 T&G SOFFIT
- 1x TRIM
- CREATE VENT GAP AT TOP OF SIDING, MIN. 1/8" CLEAR.



- PTD. GYP. BD.
- EXPOSED PAINTED WOOD TRUSSES, SEE STRUCTURAL
- SIP ROOF CONNECTION TO WALL PER MFGR'S. SPECIFICATIONS
- VERIFY WITH TRUSS MFGR. AND STRUCTURAL ENGINEER

MULTI-PURPOSE SPACE

Wall Assembly



SEE NOTES FOR FOUNDATION ON SECTION 4-A3.3

SEE STRUCTURAL DRAWINGS FOR FOUNDATION AND FOOTING DETAILS

Mechanical Systems

Outdoor Unit 1

- Spaces Unit Serves: 3 Classrooms & Corridor (2237 sf)
- Heating Capacity: 48,000 Btu/h
 - 21.5 Btu/h / sf
- Cooling Capacity: 42,000 Btu/h
 - 640 sf/ton

Outdoor Unit 2

- Spaces Unit Serves: Multi-Purpose Room, Hallway & 2 Bathrooms (3133 sf)
- Heating Capacity: 80,000 Btu/h
 - 25.5 Btu/h / sf
- Cooling Capacity: 72,000 Btu/h
 - 522 sf/ton

Project Cost: \$2 Million - \$329/sf

DISCUSSION/ QUESTIONS



Multifamily Case Studies


Simple Systems – Emerald Hills




Location	Size	Population	Envelope	HVAC	Ventilation	HW System
Pittsburgh	55 Apartments	Senior Housing	Walls: R37 Roof: R53 Windows: 3-pane	Ducted - Split Heat Pumps	Semi-Central ERVs	Condensing Gas

KEYNOTES

1 DOG HOUSE ROOF CURB FOR L CONDUIT. SEE DETAIL 10 ON S1



1. One-one heat pumps (cold climate)
2. Neighborhood ERVs
3. Gas – Central HW Heaters



1 ROOF MECHANICAL DUCTWORK PLAN
 SCALE: 1/8" = 1'-0"

Emerald Hills - DHW

Domestic HW generated by condensing gas HW heaters. Three 199,000 BTU/hr sealed combustion heaters.




Edgewood



Location	Size	Population	Envelope	HVAC	Ventilation	HW System
Pittsburgh	55 Apartments	Senior Housing	Walls: R37 Roof: R53 Windows: 2-pane	EPHOCA All-In-One units	EPHOCA All-In-One units	CO2 Heat Pumps




Edgewood



Edgewood





Old Colony | Boston

- ~1,000,000 SF
- 830 Units
- 23 Buildings
- 10 Phases
- 4 Passive House Buildings



Phase 3C

Old Colony Phase 4 & 5





Glossary

- **HRV:** Heat Recovery Ventilator – recovers heat from the exhaust air leaving a building and transfers it to the incoming fresh outdoor air, without exchanging moisture.
- **ERV:** Energy Recovery Ventilator – recovers energy from the exhaust air of a building and uses it to condition incoming fresh outdoor air.
- **DOAS:** Dedicated Outside Air System – supplies fresh outdoor air to a building’s interior independently of the heating and cooling system. This system delivers the necessary ventilation to maintain indoor air quality.
- **CAR:** Constant Airflow Regulator – used to maintain a consistent airflow rate in duct systems, regardless of changes in pressure.
- **DX:** Direct Expansion – refrigerant directly absorbs heat from the air or another medium as it expands or evaporates within the evaporator coil.
- **VRF:** Variable Refrigerant Flow – provides efficient heating and cooling by varying the flow of refrigerant to multiple indoor units.
- **ASHP:** Air Source Heat Pump – transfers heat between the indoor and outdoor air.

Old Colony Project Timeline – Heating & Cooling

Phase 1

2010

- 2-pipe changeover
- Gas boiler
- AC chiller
- Vertical fan coils

Phase 2A,
2B & 2C

2011

- Same as Phase 1

Phase 3A
& 3B

2018-
2019

- Central gas
- Hydronic heating with DX cooling – cooling bill is on tenant

Phase
3C - PH

2019

- Central VRF
- 55+ housing – funding differed from other phases

Phase 4
& 5 - PH

2020-
2021

- Individual ASHP – heating and cooling bill is on tenant

Phase
6 - PH

2022

- Central VRF

Old Colony Project Timeline - Ventilation

Phase 1

2010

Phase 2A,
2B & 2C

2011

Phase 3A

& 3B

2018-

2019

Phase
3C - PH

2019

Phase 4

& 5 - PH

2020-

2021

Phase

6 - PH

2022

- Central penthouse DOAS
- Hydronic heating and cooling supply to living room only with CAR
- Ducted range hoods – DHCD required

Midrise:

- Central rooftop DOAS ERV with packaged DX
- Gas heating
- Otherwise, same as Phase 1

Midrise Flats:

- Individual HRVs ducted to living room


- Same as Phase 2A, 2B, & 2C

- Central rooftop DOAS ERV with packaged DX
- Gas heating
- Ducted to living room and bedrooms with CAR
- Recric range hoods

- Central rooftop DOAS ERV with remote heat pump
- Otherwise, same as Phase 3C

- Same as Phase 4 & 5


Old Colony Project Timeline – Domestic Hot Water



Old Colony Phase 6 – Case Study



1 Bedroom Typical Duct Layout




CAR Damper Drama

American Aldes CAR3

NEW



CAR3 4" Diameter





CAR DAMPER TESTING

6/04/2024 by Sarah Carter, P.E.

General Requirements

1. Constant Air Regulator (CAR) dampers, particularly within the ceiling box/grille/damper assembly, are difficult to reliably test in the field with traditional flow hood due to turbulence at the air outlet.
2. All fan systems shall have an external static pressure calculation prepared by the engineer of record. The purpose of the calculation is to ensure that there is appropriate static pressure at all points in the ductwork.
3. CAR dampers are factory set and tested, they should work properly if the inlet pressure is within range, typically 0.12 to 1.2 IN WG.
4. Provide a sample of the CAR damper to EOR as part of submittal process.



CAR DAMPER TESTING

6/04/2024 by Sarah Carter, P.E.

Base Measuring/Verification Requirements

1. Measure the inlet pressure at CAR damper with a manometer at most remote location and nearest to ERV and verify that all duct static pressures fall within the CAR damper manufacturer's published pressure range.
 - a. In lieu of measuring static pressure at the inlet of the damper, static pressure may also be measured at the main in the corridor. This represents the maximum available static pressure to the car damper. Note however that it doesn't include branch duct losses between the duct main and the damper.
2. Perform visual check to make sure the damper is operating freely (not at its maximum or minimum position but somewhere in between).



Petersen
Engineering

STANDARD OPERATING PROCEDURE

For Internal Use Only

CAR DAMPER TESTING

6/04/2024 by Sarah Carter, P.E.

Audit Measures

1. Bag Inflation Device per RESNET 380 Standard is an acceptable method for verifying proper operation of CAR damper for supply application. This can be done as a sampling method.
2. Provide a traverse at ERV and halfway down main duct within a straight piece of duct, for both outdoor air and exhaust air ducts.

ANSI/RESNET/ICC 380-2022

6.3. Procedure to measure airflow at outlet terminal.

This Section defines procedures to measure the airflow of a mechanical Ventilation system at an outlet terminal. The airflow is permitted to be measured using a powered flow hood (Section 6.3.1), a bag inflation device (Section 6.3.2), or a vane anemometer with hood (Section 6.3.3).

6.3.1. Powered flow hood. To measure airflow at an outlet terminal using a powered flow hood, Section 6.2.1 shall be followed except with all occurrences of the phrase “inlet terminal” replaced with “outlet terminal.”

6.3.2. Bag inflation device.

6.3.2.1. Equipment needed.

6.3.2.1.1. Bag inflation device. A flow capture element capable of creating an airtight perimeter seal around the outlet terminal that is connected to a plastic bag of known volume and holding the bag open⁶⁷ and a shutter that controls airflow into the bag.

The plastic bag shall be selected such that three or more measurements of a single outlet terminal produce results that are within 20 percent of each other.

The volume of the plastic bag shall be selected such that the bag will completely fill with air from the outlet terminal in the range of 3 to 20 seconds.

6.3.2.1.2. Stopwatch. A stopwatch capable of recording elapsed time +/- 0.1 seconds.

6.3.2.2. Procedure to conduct airflow test.

ANSI/RESNET/ICC 380-2022

- 6.3.2.2.1. The bag shall be completely emptied of air, and the shutter shall be closed to prevent airflow into the bag.
- 6.3.2.2.2. The bag inflation device shall be placed over the outlet terminal.
- 6.3.2.2.3. The shutter shall be removed rapidly, and the stopwatch started.
- 6.3.2.2.4. The stopwatch shall be stopped when the bag is completely filled with air from the outlet terminal, and the elapsed time is recorded.
- 6.3.2.2.5. The airflow shall be calculated using Equation 6.3-1a or 6.3-1b

$$\text{Airflow (CFM)} = \frac{8 \times \text{Volume}}{\text{Elapsed Time}} \quad \text{(Equation 6.3-1a)}$$

$$\text{Airflow (L/s)} = \frac{4 \times \text{Volume}}{\text{Elapsed Time}} \quad \text{(Equation 6.3-1b)}$$

where: Volume = The volume of the plastic bag, in gallons.

Elapsed Time = The time that elapsed until the bag was filled, in seconds.

6.3.3 Vane anemometer with hood. To measure airflow at an outlet terminal using a vane anemometer with hood, Section 6.2.4 shall be followed except with all occurrences of the phrase “inlet terminal” replaced with “outlet terminal.”

Duct Tightness Requirements

DUCT LEAK CLASS AND SEALING SCHEDULE							
TYPE	DUCT PRESSURE CLASS	SEAL CLASS	SEALING APPLICABLE	AEROSEAL REQUIRED	SMACNA LEAKAGE CLASS	RECOMMENDED TEST PRESSURE	NOTES
CENTRAL VENTILATION ERV ROUND DUCT	3"	A	JOINTS, SEAMS AND ALL WALL PENETRATION	YES	3	1"	1, 2
CENTRAL VENTILATION ERV RECTANGULAR DUCT	3"	A	JOINTS, SEAMS AND ALL WALL PENETRATION	YES	6	1"	1, 2
APARTMENT FAN COIL SUPPLY AND RETURN ROUND DUCT	2"	A	JOINTS, SEAMS AND ALL WALL PENETRATION	NO	3	1"	1, 2
APARTMENT FAN COIL SUPPLY AND RETURN RECTANGULAR DUCT	2"	A	JOINTS, SEAMS AND ALL WALL PENETRATION	NO	6	1"	1, 2
<p>1. REFER TO SMACNA HVAC AIR DUCT LEAK TEST MANUAL, FIGURE 4-1 FOR ALLOWABLE LEAKAGE RATES AT DIFFERENT TEST PRESSURES.</p> <p>2. DO NOT EXCEED DUCT PRESSURE CLASS WHEN LEAK TESTING.</p>							

Hot Water Use Data


Old Colony Phase 3 - Domestic Hot Water Use

Domestic Water Use in Building 3A1 and 3C 99th Percentile (Max) - Peak Flow Rates		
Building	Date	Hot GPM
Building 3A1 (multifamily)	5/10/2023	12.0 (16.7)
Building 3A1 (multifamily)	5/25/2023	11.9 (21.0)
Building 3C (55 + 1-bdrm)	6/6/2023	1.0 (4.0)
Building 3C (55 + 1-bdrm)	7/12/2023	0.9 (4.0)


Domestic Hot Water Use Per Person				
Building	Total Hot GPD	# bedrooms	# people	DHW gal/person/day
Building 3A1 (multifamily)	4,832	187	374	13
Building 3A1 (multifamily)	4,840	187	374	13
Building 3C (55 + 1-bdrm)	1,017	55	110	9
Building 3C (55 + 1-bdrm)	1,038	55	110	9

We had one data point of measured hot water from OCA at time of issuance of OC6 permit set which was 13 gal/person/day. Based on optimizing the equipment size availability for the air source heat pumps and storage tanks that are all provided as a packaged system from the vendor, we landed on DHW plant capable of 20 gal/person/day

Old Colony Phase 3A - Domestic Hot Water Use - GPD



Old Colony Phase 3A - Domestic Hot Water Use - GPM



Design Exercise and Discussion

Outdoor DHW Heat Pumps



Image Courtesy of Sanden



Image Courtesy of Mitsubishi



Image Courtesy of Lync


C02 Refrigerant Heat Pumps

1. Operate down to very low ambient temperatures
2. Can generate very hot water (160-180 degrees F)
3. High COPs!
4. Low greenhouse gas content

GS4-45HPC COP Values




COP is defined as the ratio of Capacity/Power Input



Central System Design

- Swing Tank is for Recirculation



From: SanC02 Multi-Family Design Strategy

Mechanical Systems for Multifamily Deep Energy Retrofits



- Retrofit relevance
- The problem
- Electrification - re-inventing fire?
- The big idea (solution approach)
- System approaches
- Case Study (Colonial II)
- Mechanical Pod Development

Galen Staengl, PE, LEED BD+C CHPC

The Importance of Deep Energy Retrofits

Residential delivered energy intensity
million British thermal units per household






Figure ES3. Base Case Energy Use



The Opportunity

- Total Housing Units in the US: ~ 145,000,000
- New Housing Units: ~ 1%/year

Deep Energy Retrofits are key to reducing the carbon intensity of the housing sector.



U.S. Building Stock Characterization Study A National Typology for Decarbonizing U.S. Buildings

Janet Reyna,¹ Eric Wilson,¹ Andrew Parker,¹ Aven Satre-Meloy,² Amy Egerter,³ Carlo Bianchi,¹ Marlena Praprost,¹ Andrew Speake,¹ Lixi Liu,¹ Ry Horsey,¹ Matthew Dahlhausen,¹ Christopher CaraDonna,¹ and Stacey Rothgeb¹

*1 National Renewable Energy Laboratory
2 Lawrence Berkeley National Laboratory
3 Rocky Mountain Institute*

NREL is a national laboratory of the U.S. Department of Energy
Office of Energy Efficiency & Renewable Energy
Operated by the Alliance for Sustainable Energy, LLC

This report is available at no cost from the National Renewable Energy
Laboratory (NREL) at www.nrel.gov/publications.

Contract No. DE-AC36-08GO28308

Technical Report
NREL/TP-5500-83063
Revised July 2022

Residential Segments - Mixed-Humid




Figure 10. Residential Mixed-Humid typology segments

Residential Segments - Cold & Very Cold




Figure 7. Residential Cold/Very-Cold typology segments

Residential Segments - Hot-Dry & Mixed-Dry




Figure 16. Residential Hot-Dry/Mixed-Dry typology segments

Residential Segments - Hot-Humid




Figure 19. Residential Hot-Humid typology segments





Objectives:

- Dramatic Building Energy Savings (>50%)
- Retrofit-in-place
- Electrification

Challenges:

- Limitations on exterior insulation
- Electrical service capacity
- Equipment availability
- COST







Electrification

- Benefits
 - Carbon reduction
 - Safety
 - IAQ
 - Local Air Quality
- Barriers
 - Heating loads
 - Electrical Infrastructure
 - Relative cost of Gas / Electricity
 - Immature heat pump market in the US
 - Outside design temperature?


Insulate the Envelope



Exteri




Interi



System Approach

Can we penetrate the exterior envelope?

- Historic Envelope?
- Lot Line Issues?




System Approach

Can we penetrate the exterior envelope?

YES – Apartment Level Solutions

- Ventilation and Condenser Air F




System Approach

If we can't penetrate the exterior: Can we fit ductwork in the corridor?

YES

- Ventilation Air from Rooftop DOAS/ERV
- Space Conditioning:
 - Water source heat pumps?
 - Hydronic fan coils?
 - VRF?
- Heat Pump Based Central Plant:
 - Air Source Heat Pumps?
 - Geothermal?
 - Solar HW?
 - VRF?



System Approach


4-pipe or 2-pipe hydronic system

Advantages

- High Efficiency
- Opportunities for heat recovery to domestic hot water in central DHW system

Disadvantages

- Cost of piping is high if not already there



System Approach


Water-source heat pumps

Advantages

- Neutral water piped through the building. Can re-use existing heating water piping
- Can capture waste heat for domestic hot water heating in a central DHW plant

Disadvantages

- Compressor in every apartment



System Approach


Ground / Solar-source heat pumps

Advantages

- Very low energy use
- Can be integrated with solar
- Lower maintenance costs
- Heat recovery to DHW possible

Disadvantages

- Requires real estate for ground loop
- High cost, but lower now with tax credits available,



System Approach

VRF

Advantages

- Less costly than hydronic

Disadvantages

- Requires refrigerant line-sets to be run throughout the building
- High potential refrigerant loss, with high global warming potential
- High embodied carbon content of refrigerant
- High maintenance costs

